


Area Type Averages

Building type: College/University. Building size: 50K to less than 100K. Shifts: 1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	2	912	129.19	0.00	0.00	0.00	129.19	44.42	0.00	0.00	0.00	44.42	65.62%
Restroom	R	3	256	153.06	0.00	0.00	0.00	153.06	22.45	0.00	0.00	0.00	22.45	85.33%
Classroom	CR	1	576	25.15	0.00	0.00	0.00	25.15	14.87	0.00	0.00	0.00	14.87	40.87%
Lobby	LB	3	792	167.98	0.00	0.00	0.00	167.98	80.23	0.00	0.00	0.00	80.23	52.24%
Building Average			5544	138.31			0.00	138.31	53.65			0.00	53.65	61.21%



Hours per Week for each Area Type

Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
22848	Restroom	R	172.25	172.25	0.00	0.00	0.00	11/04/05 7:46 PM	11/12/05 12:00	149.12	0.00	0.00	0.00	149.12	35.62	0.00	0.00	0.00	35.62
23367	Classroom	CR	166.80	166.80	0.00	0.00	0.00	11/04/05 8:10 PM	11/11/05 6:57 PM	24.97	0.00	0.00	0.00	24.97	14.77	0.00	0.00	0.00	14.77
22815	Restroom	R	166.38	166.38	0.00	0.00	0.00	11/04/05 8:46 PM	11/11/05 7:08 PM	166.37	0.00	0.00	0.00	166.37	16.43	0.00	0.00	0.00	16.43
22259	Meeting Rooms	M	166.30	166.30	0.00	0.00	0.00	11/04/05 8:56 PM	11/11/05 7:13 PM	100.40	0.00	0.00	0.00	100.40	34.13	0.00	0.00	0.00	34.13
24170	Restroom	R	166.12	166.12	0.00	0.00	0.00	11/04/05 9:10 PM	11/11/05 7:16 PM	144.13	0.00	0.00	0.00	144.13	15.83	0.00	0.00	0.00	15.83
22133	Lobby	LB	166.12	166.12	0.00	0.00	0.00	11/04/05 9:05 PM	11/11/05 7:11 PM	166.10	0.00	0.00	0.00	166.10	75.58	0.00	0.00	0.00	75.58
21024	Lobby	LB	166.08	166.08	0.00	0.00	0.00	11/04/05 9:14 PM	11/11/05 7:18 PM	166.07	0.00	0.00	0.00	166.07	78.37	0.00	0.00	0.00	78.37
23055	Meeting Rooms	M	165.95	165.95	0.00	0.00	0.00	11/04/05 9:23 PM	11/11/05 7:19 PM	155.03	0.00	0.00	0.00	155.03	53.70	0.00	0.00	0.00	53.70
22778	Lobby	LB	166.07	166.07	0.00	0.00	0.00	11/04/05 9:20 PM	11/11/05 7:23 PM	166.05	0.00	0.00	0.00	166.05	84.02	0.00	0.00	0.00	84.02

Normalized Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
22848	Restroom	R	256	145.44	0.00	0.00	0.00	145.44	34.74	0.00	0.00	0.00	34.74	76.11%
23367	Classroom	CR	576	25.15	0.00	0.00	0.00	25.15	14.87	0.00	0.00	0.00	14.87	40.87%
22815	Restroom	R	256	167.98	0.00	0.00	0.00	167.98	16.59	0.00	0.00	0.00	16.59	90.12%
22259	Meeting Rooms	M	960	101.43	0.00	0.00	0.00	101.43	34.48	0.00	0.00	0.00	34.48	66.01%
24170	Restroom	R	256	145.77	0.00	0.00	0.00	145.77	16.01	0.00	0.00	0.00	16.01	89.02%
22133	Lobby	LB	2176	167.98	0.00	0.00	0.00	167.98	76.44	0.00	0.00	0.00	76.44	54.49%
21024	Lobby	LB	100	167.98	0.00	0.00	0.00	167.98	79.27	0.00	0.00	0.00	79.27	52.81%
23055	Meeting Rooms	M	864	156.95	0.00	0.00	0.00	156.95	54.36	0.00	0.00	0.00	54.36	65.36%
22778	Lobby	LB	100	167.98	0.00	0.00	0.00	167.98	84.99	0.00	0.00	0.00	84.99	49.40%

Building Summary Totals Building type:College/University. Building size:50K to less than 100K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	2	1824	236	0	0	0	236	81	0	0	0	81
Restroom	R	3	768	118	0	0	0	118	17	0	0	0	17
Classroom	CR	1	576	14	0	0	0	14	9	0	0	0	9
Lobby	LB	3	2376	399	0	0	0	399	191	0	0	0	191
Building Totals			5544	767			0	767	297			0	297