


Area Type Averages

Building type:College/University. Building size:50K to less than 100K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	4	576	53.48	0.00	0.00	53.48	13.90	0.00	0.00	0.00	13.90	74.01%	
Storage	S	2	864	36.48	0.00	0.00	36.48	6.17	0.00	0.00	0.00	6.17	83.09%	
Classroom	CR	8	1440	37.64	0.00	0.00	37.64	23.76	0.00	0.00	0.00	23.76	36.88%	
Office	O	2	384	45.44	0.00	0.00	45.44	33.57	0.00	0.00	0.00	33.57	26.12%	
Computer Room	CP	2	1440	63.44	0.00	0.00	63.44	26.15	0.00	0.00	0.00	26.15	58.78%	
Building Average			19200	43.62		0.00	43.62	21.74		0.00	0.00	21.74	50.16%	



Hours per Week for each Area Type

Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
24294	Classroom	CR	347.23	347.23	0.00	0.00	0.00	11/01/05 11:47	11/15/05 11:00	95.55	0.00	0.00	0.00	95.55	60.98	0.00	0.00	0.00	60.98
24134	Classroom	CR	347.28	347.28	0.00	0.00	0.00	11/01/05 11:44	11/15/05 11:00	95.60	0.00	0.00	0.00	95.60	63.37	0.00	0.00	0.00	63.37
24226	Classroom	CR	347.25	347.25	0.00	0.00	0.00	11/01/05 11:46	11/15/05 11:00	93.38	0.00	0.00	0.00	93.38	55.82	0.00	0.00	0.00	55.82
23967	Classroom	CR	345.15	345.15	0.00	0.00	0.00	11/01/05 1:52 PM	11/15/05 11:00	76.97	0.00	0.00	0.00	76.97	47.40	0.00	0.00	0.00	47.40
22559	Classroom	CR	345.15	345.15	0.00	0.00	0.00	11/01/05 1:52 PM	11/15/05 11:00	80.70	0.00	0.00	0.00	80.70	47.70	0.00	0.00	0.00	47.70
23939	Classroom	CR	347.30	347.30	0.00	0.00	0.00	11/01/05 11:43	11/15/05 11:00	93.27	0.00	0.00	0.00	93.27	54.97	0.00	0.00	0.00	54.97
23384	Classroom	CR	348.35	348.35	0.00	0.00	0.00	11/01/05 10:40	11/15/05 11:00	11.87	0.00	0.00	0.00	11.87	10.73	0.00	0.00	0.00	10.73
24133	Classroom	CR	348.35	348.35	0.00	0.00	0.00	11/01/05 10:40	11/15/05 11:00	74.43	0.00	0.00	0.00	74.43	51.60	0.00	0.00	0.00	51.60
21745	Computer Room	CP	347.17	347.17	0.00	0.00	0.00	11/01/05 11:51	11/15/05 11:00	131.03	0.00	0.00	0.00	131.03	48.90	0.00	0.00	0.00	48.90
23953	Computer Room	CP	347.52	347.52	0.00	0.00	0.00	11/01/05 11:30	11/15/05 11:00	131.30	0.00	0.00	0.00	131.30	59.23	0.00	0.00	0.00	59.23
23395	Meeting Rooms	M	349.17	349.17	0.00	0.00	0.00	11/01/05 9:51 AM	11/15/05 11:00	183.73	0.00	0.00	0.00	183.73	42.23	0.00	0.00	0.00	42.23
23905	Meeting Rooms	M	349.20	349.20	0.00	0.00	0.00	11/01/05 9:49 AM	11/15/05 11:00	183.77	0.00	0.00	0.00	183.77	39.07	0.00	0.00	0.00	39.07
24197	Meeting Rooms	M	349.07	349.07	0.00	0.00	0.00	11/01/05 9:57 AM	11/15/05 11:00	38.53	0.00	0.00	0.00	38.53	17.40	0.00	0.00	0.00	17.40
22691	Meeting Rooms	M	349.07	349.07	0.00	0.00	0.00	11/01/05 9:57 AM	11/15/05 11:00	38.53	0.00	0.00	0.00	38.53	16.90	0.00	0.00	0.00	16.90
24644	Office	O	346.83	346.83	0.00	0.00	0.00	11/01/05 12:11	11/15/05 11:00	93.83	0.00	0.00	0.00	93.83	70.40	0.00	0.00	0.00	70.40
24107	Office	O	346.83	346.83	0.00	0.00	0.00	11/01/05 12:11	11/15/05 11:00	93.77	0.00	0.00	0.00	93.77	68.20	0.00	0.00	0.00	68.20
21041	Storage	S	348.92	348.92	0.00	0.00	0.00	11/01/05 10:06	11/15/05 11:00	75.77	0.00	0.00	0.00	75.77	12.50	0.00	0.00	0.00	12.50
24232	Storage	S	348.90	348.90	0.00	0.00	0.00	11/01/05 10:07	11/15/05 11:00	75.73	0.00	0.00	0.00	75.73	13.13	0.00	0.00	0.00	13.13

Normalized Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24294	Classroom	CR	1728	46.23	0.00	0.00	0.00	46.23	29.51	0.00	0.00	0.00	29.51	36.17%
24134	Classroom	CR	1728	46.25	0.00	0.00	0.00	46.25	30.65	0.00	0.00	0.00	30.65	33.73%
24226	Classroom	CR	1728	45.18	0.00	0.00	0.00	45.18	27.00	0.00	0.00	0.00	27.00	40.24%
23967	Classroom	CR	1152	37.46	0.00	0.00	0.00	37.46	23.07	0.00	0.00	0.00	23.07	38.41%
22559	Classroom	CR	1152	39.28	0.00	0.00	0.00	39.28	23.22	0.00	0.00	0.00	23.22	40.89%
23939	Classroom	CR	1728	45.12	0.00	0.00	0.00	45.12	26.59	0.00	0.00	0.00	26.59	41.07%
23384	Classroom	CR	1152	5.72	0.00	0.00	0.00	5.72	5.18	0.00	0.00	0.00	5.18	9.44%
24133	Classroom	CR	1152	35.90	0.00	0.00	0.00	35.90	24.89	0.00	0.00	0.00	24.89	30.67%
21745	Computer	CP	1440	63.41	0.00	0.00	0.00	63.41	23.66	0.00	0.00	0.00	23.66	62.69%
23953	Computer	CP	1440	63.47	0.00	0.00	0.00	63.47	28.64	0.00	0.00	0.00	28.64	54.88%
23395	Meeting Rooms	M	576	88.40	0.00	0.00	0.00	88.40	20.32	0.00	0.00	0.00	20.32	77.01%
23905	Meeting Rooms	M	576	88.41	0.00	0.00	0.00	88.41	18.79	0.00	0.00	0.00	18.79	78.75%
24197	Meeting Rooms	M	576	18.55	0.00	0.00	0.00	18.55	8.37	0.00	0.00	0.00	8.37	54.88%
22691	Meeting Rooms	M	576	18.55	0.00	0.00	0.00	18.55	8.13	0.00	0.00	0.00	8.13	56.17%
24644	Office	O	384	45.45	0.00	0.00	0.00	45.45	34.10	0.00	0.00	0.00	34.10	24.97%
24107	Office	O	384	45.42	0.00	0.00	0.00	45.42	33.03	0.00	0.00	0.00	33.03	27.28%
21041	Storage	S	864	36.48	0.00	0.00	0.00	36.48	6.02	0.00	0.00	0.00	6.02	83.50%
24232	Storage	S	864	36.47	0.00	0.00	0.00	36.47	6.32	0.00	0.00	0.00	6.32	82.67%

Building Summary Totals Building type:College/University. Building size:50K to less than 100K. Shifts:2

Building Summary Totals				Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Meeting Rooms		M	4	2304	123	0	0	123	32	0	0	0	32	
Storage		S	2	1728	63	0	0	63	11	0	0	0	11	
Classroom		CR	8	11520	434	0	0	434	274	0	0	0	274	
Office		O	2	768	35	0	0	35	26	0	0	0	26	
Computer Room		CP	2	2880	183	0	0	183	75	0	0	0	75	
Building Totals				19200	837			0	837	417				417