


Area Type Averages

Building type:College/University. Building size:50K to less than 100K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	4	576	53.53	0.00	0.00	53.53	14.54	0.00	0.00	0.00	14.54	72.84%	
Storage	S	2	864	36.54	0.00	0.00	36.54	6.53	0.00	0.00	0.00	6.53	82.13%	
Classroom	CR	8	1440	41.86	0.00	0.00	41.86	27.07	0.00	0.00	0.00	27.07	35.33%	
Office	O	2	384	45.47	0.00	0.00	45.47	33.67	0.00	0.00	0.00	33.67	25.95%	
Computer Room	CP	2	1440	63.58	0.00	0.00	63.58	30.33	0.00	0.00	0.00	30.33	52.30%	
Building Average			19200	46.18		0.00	46.18	24.47		0.00	0.00	24.47	47.01%	



Hours per Week for each Area Type

Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
24294	Classroom	CR	347.23	347.23	0.00	0.00	0.00	11/01/05 11:47	11/15/05 11:00	95.55	0.00	0.00	0.00	95.55	60.98	0.00	0.00	0.00	60.98
24134	Classroom	CR	347.28	347.28	0.00	0.00	0.00	11/01/05 11:44	11/15/05 11:00	95.60	0.00	0.00	0.00	95.60	63.37	0.00	0.00	0.00	63.37
24226	Classroom	CR	347.25	347.25	0.00	0.00	0.00	11/01/05 11:46	11/15/05 11:00	93.38	0.00	0.00	0.00	93.38	55.82	0.00	0.00	0.00	55.82
1	Classroom	CR	347.30	347.30	0.00	0.00	0.00	11/01/05 11:43	11/15/05 11:00	96.53	0.00	0.00	0.00	96.53	65.70	0.00	0.00	0.00	65.70
2	Classroom	CR	345.15	345.15	0.00	0.00	0.00	11/01/05 1:52 PM	11/15/05 11:00	80.92	0.00	0.00	0.00	80.92	49.78	0.00	0.00	0.00	49.78
22559	Classroom	CR	345.15	345.15	0.00	0.00	0.00	11/01/05 1:52 PM	11/15/05 11:00	80.70	0.00	0.00	0.00	80.70	47.70	0.00	0.00	0.00	47.70
3	Classroom	CR	348.35	348.35	0.00	0.00	0.00	11/01/05 10:40	11/15/05 11:00	74.52	0.00	0.00	0.00	74.52	52.48	0.00	0.00	0.00	52.48
24133	Classroom	CR	348.35	348.35	0.00	0.00	0.00	11/01/05 10:40	11/15/05 11:00	74.43	0.00	0.00	0.00	74.43	51.60	0.00	0.00	0.00	51.60
4	Computer Room	CP	347.52	347.52	0.00	0.00	0.00	11/01/05 11:30	11/15/05 11:00	131.75	0.00	0.00	0.00	131.75	66.23	0.00	0.00	0.00	66.23
23953	Computer Room	CP	347.52	347.52	0.00	0.00	0.00	11/01/05 11:30	11/15/05 11:00	131.30	0.00	0.00	0.00	131.30	59.23	0.00	0.00	0.00	59.23
23395	Meeting Rooms	M	349.17	349.17	0.00	0.00	0.00	11/01/05 9:51 AM	11/15/05 11:00	183.73	0.00	0.00	0.00	183.73	42.23	0.00	0.00	0.00	42.23
5	Meeting Rooms	M	349.20	349.20	0.00	0.00	0.00	11/01/05 9:49 AM	11/15/05 11:00	183.93	0.00	0.00	0.00	183.93	43.60	0.00	0.00	0.00	43.60
24197	Meeting Rooms	M	349.07	349.07	0.00	0.00	0.00	11/01/05 9:57 AM	11/15/05 11:00	38.53	0.00	0.00	0.00	38.53	17.40	0.00	0.00	0.00	17.40
6	Meeting Rooms	M	349.07	349.07	0.00	0.00	0.00	11/01/05 9:57 AM	11/15/05 11:00	38.77	0.00	0.00	0.00	38.77	17.67	0.00	0.00	0.00	17.67
7	Office	O	346.83	346.83	0.00	0.00	0.00	11/01/05 12:11	11/15/05 11:00	93.98	0.00	0.00	0.00	93.98	70.82	0.00	0.00	0.00	70.82
24107	Office	O	346.83	346.83	0.00	0.00	0.00	11/01/05 12:11	11/15/05 11:00	93.77	0.00	0.00	0.00	93.77	68.20	0.00	0.00	0.00	68.20
21041	Storage	S	348.92	348.92	0.00	0.00	0.00	11/01/05 10:06	11/15/05 11:00	75.77	0.00	0.00	0.00	75.77	12.50	0.00	0.00	0.00	12.50
8	Storage	S	348.92	348.92	0.00	0.00	0.00	11/01/05 10:06	11/15/05 11:00	76.00	0.00	0.00	0.00	76.00	14.60	0.00	0.00	0.00	14.60

Normalized Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24294	Classroom	CR	1728	46.23	0.00	0.00	0.00	46.23	29.51	0.00	0.00	0.00	29.51	36.17%
24134	Classroom	CR	1728	46.25	0.00	0.00	0.00	46.25	30.65	0.00	0.00	0.00	30.65	33.73%
24226	Classroom	CR	1728	45.18	0.00	0.00	0.00	45.18	27.00	0.00	0.00	0.00	27.00	40.24%
1	Classroom	CR	1728	46.70	0.00	0.00	0.00	46.70	31.78	0.00	0.00	0.00	31.78	31.95%
2	Classroom	CR	1152	39.39	0.00	0.00	0.00	39.39	24.23	0.00	0.00	0.00	24.23	38.49%
22559	Classroom	CR	1152	39.28	0.00	0.00	0.00	39.28	23.22	0.00	0.00	0.00	23.22	40.89%
3	Classroom	CR	1152	35.94	0.00	0.00	0.00	35.94	25.31	0.00	0.00	0.00	25.31	29.58%
24133	Classroom	CR	1152	35.90	0.00	0.00	0.00	35.90	24.89	0.00	0.00	0.00	24.89	30.67%
4	Computer	CP	1440	63.69	0.00	0.00	0.00	63.69	32.02	0.00	0.00	0.00	32.02	49.73%
23953	Computer	CP	1440	63.47	0.00	0.00	0.00	63.47	28.64	0.00	0.00	0.00	28.64	54.88%
23395	Meeting Rooms	M	576	88.40	0.00	0.00	0.00	88.40	20.32	0.00	0.00	0.00	20.32	77.01%
5	Meeting Rooms	M	576	88.49	0.00	0.00	0.00	88.49	20.98	0.00	0.00	0.00	20.98	76.29%
24197	Meeting Rooms	M	576	18.55	0.00	0.00	0.00	18.55	8.37	0.00	0.00	0.00	8.37	54.88%
6	Meeting Rooms	M	576	18.66	0.00	0.00	0.00	18.66	8.50	0.00	0.00	0.00	8.50	54.45%
7	Office	O	384	45.52	0.00	0.00	0.00	45.52	34.30	0.00	0.00	0.00	34.30	24.65%
24107	Office	O	384	45.42	0.00	0.00	0.00	45.42	33.03	0.00	0.00	0.00	33.03	27.28%
21041	Storage	S	864	36.48	0.00	0.00	0.00	36.48	6.02	0.00	0.00	0.00	6.02	83.50%
8	Storage	S	864	36.59	0.00	0.00	0.00	36.59	7.03	0.00	0.00	0.00	7.03	80.79%

Building Summary Totals Building type:College/University. Building size:50K to less than 100K. Shifts:2

Building Summary Totals				Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Meeting Rooms		M	4	2304	123	0	0	123	34	0	0	0	34	
Storage		S	2	1728	63	0	0	63	11	0	0	0	11	
Classroom		CR	8	11520	482	0	0	482	312	0	0	0	312	
Office		O	2	768	35	0	0	35	26	0	0	0	26	
Computer Room		CP	2	2880	183	0	0	183	87	0	0	0	87	
Building Totals				19200	887			0	887	470				470