


Area Type Averages

Building type:College/University. Building size:50K to less than 100K. Shifts:2

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	2	576	53.58	0.00	0.00	0.00	53.58	14.74	0.00	0.00	0.00	14.74	72.49%
Storage	S	1	864	36.59	0.00	0.00	0.00	36.59	7.03	0.00	0.00	0.00	7.03	80.79%
Classroom	CR	4	1440	42.07	0.00	0.00	0.00	42.07	27.71	0.00	0.00	0.00	27.71	34.13%
Office	O	1	384	45.52	0.00	0.00	0.00	45.52	34.30	0.00	0.00	0.00	34.30	24.65%
Computer Room	CP	1	1440	63.69	0.00	0.00	0.00	63.69	32.02	0.00	0.00	0.00	32.02	49.73%
Building Average			9600	46.34			0.00	46.34	25.20			0.00	25.20	45.62%



Hours per Week for each Area Type

Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
1	Classroom	CR	347.30	347.30	0.00	0.00	0.00	11/01/05 11:43	11/15/05 11:00	96.53	0.00	0.00	0.00	96.53	65.70	0.00	0.00	0.00	65.70
24294	Classroom	CR	347.23	347.23	0.00	0.00	0.00	11/01/05 11:47	11/15/05 11:00	95.55	0.00	0.00	0.00	95.55	60.98	0.00	0.00	0.00	60.98
2	Classroom	CR	345.15	345.15	0.00	0.00	0.00	11/01/05 1:52 PM	11/15/05 11:00	80.92	0.00	0.00	0.00	80.92	49.78	0.00	0.00	0.00	49.78
3	Classroom	CR	348.35	348.35	0.00	0.00	0.00	11/01/05 10:40	11/15/05 11:00	74.52	0.00	0.00	0.00	74.52	52.48	0.00	0.00	0.00	52.48
4	Computer Room	CP	347.52	347.52	0.00	0.00	0.00	11/01/05 11:30	11/15/05 11:00	131.75	0.00	0.00	0.00	131.75	66.23	0.00	0.00	0.00	66.23
5	Meeting Rooms	M	349.20	349.20	0.00	0.00	0.00	11/01/05 9:49 AM	11/15/05 11:00	183.93	0.00	0.00	0.00	183.93	43.60	0.00	0.00	0.00	43.60
6	Meeting Rooms	M	349.07	349.07	0.00	0.00	0.00	11/01/05 9:57 AM	11/15/05 11:00	38.77	0.00	0.00	0.00	38.77	17.67	0.00	0.00	0.00	17.67
7	Office	O	346.83	346.83	0.00	0.00	0.00	11/01/05 12:11	11/15/05 11:00	93.98	0.00	0.00	0.00	93.98	70.82	0.00	0.00	0.00	70.82
8	Storage	S	348.92	348.92	0.00	0.00	0.00	11/01/05 10:06	11/15/05 11:00	76.00	0.00	0.00	0.00	76.00	14.60	0.00	0.00	0.00	14.60

Normalized Data Logger Detail Building type:College/University. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
1	Classroom	CR	1728	46.70	0.00	0.00	0.00	46.70	31.78	0.00	0.00	0.00	31.78	31.95%
24294	Classroom	CR	1728	46.23	0.00	0.00	0.00	46.23	29.51	0.00	0.00	0.00	29.51	36.17%
2	Classroom	CR	1152	39.39	0.00	0.00	0.00	39.39	24.23	0.00	0.00	0.00	24.23	38.49%
3	Classroom	CR	1152	35.94	0.00	0.00	0.00	35.94	25.31	0.00	0.00	0.00	25.31	29.58%
4	Computer	CP	1440	63.69	0.00	0.00	0.00	63.69	32.02	0.00	0.00	0.00	32.02	49.73%
5	Meeting Rooms	M	576	88.49	0.00	0.00	0.00	88.49	20.98	0.00	0.00	0.00	20.98	76.29%
6	Meeting Rooms	M	576	18.66	0.00	0.00	0.00	18.66	8.50	0.00	0.00	0.00	8.50	54.45%
7	Office	O	384	45.52	0.00	0.00	0.00	45.52	34.30	0.00	0.00	0.00	34.30	24.65%
8	Storage	S	864	36.59	0.00	0.00	0.00	36.59	7.03	0.00	0.00	0.00	7.03	80.79%

Building Summary Totals Building type:College/University. Building size:50K to less than 100K. Shifts:2

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	2	1152	62	0	0	0	62	17	0	0	0	17
Storage	S	1	864	32	0	0	0	32	6	0	0	0	6
Classroom	CR	4	5760	242	0	0	0	242	160	0	0	0	160
Office	O	1	384	17	0	0	0	17	13	0	0	0	13
Computer Room	CP	1	1440	92	0	0	0	92	46	0	0	0	46
Building Totals			9600	445			0	445	242			0	242