


Area Type Averages

Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	1	120	14.14	0.00	0.00	0.00	14.14	12.44	0.00	0.00	0.00	12.44	12.02%
Hallway	H	1	600	56.17	0.00	0.00	0.00	56.17	21.28	0.00	0.00	0.00	21.28	62.12%
Classroom	CR	2	636	17.49	0.00	0.00	0.00	17.49	14.80	0.00	0.00	0.00	14.80	15.38%
Gym	G	1	6370	20.73	0.00	0.00	0.00	20.73	12.24	0.00	0.00	0.00	12.24	40.96%
Kitchen	K	1	521	11.61	0.00	0.00	0.00	11.61	4.70	0.00	0.00	0.00	4.70	59.52%
Office	O	1	1150	44.01	0.00	0.00	0.00	44.01	38.25	0.00	0.00	0.00	38.25	13.09%
Building Average			10033	24.55			0.00	24.55	15.70			0.00	15.70	36.05%



Hours per Week for each Area Type

Data Logger Detail Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
21077	Classroom	CR	2093.18	2093.18	0.00	0.00	0.00	7/11/05 9:47 AM	10/06/05 2:57 PM	261.87	0.00	0.00	0.00	261.87	222.63	0.00	0.00	0.00	222.63
20752	Classroom	CR	2380.58	2380.58	0.00	0.00	0.00	6/29/05 10:17 AM	10/06/05 2:51 PM	197.72	0.00	0.00	0.00	197.72	166.07	0.00	0.00	0.00	166.07
21348	Hallway	H	2380.67	2380.67	0.00	0.00	0.00	6/29/05 10:14 AM	10/06/05 2:53 PM	796.00	0.00	0.00	0.00	796.00	301.58	0.00	0.00	0.00	301.58
20807	Kitchen	K	2238.32	2238.32	0.00	0.00	0.00	7/05/05 8:27 AM	10/06/05 2:45 PM	154.73	0.00	0.00	0.00	154.73	62.63	0.00	0.00	0.00	62.63
21764	Office	O	2380.00	2380.00	0.00	0.00	0.00	6/29/05 10:50 AM	10/06/05 2:49 PM	623.50	0.00	0.00	0.00	623.50	541.83	0.00	0.00	0.00	541.83
22368	Private Office	PO	2217.17	2217.17	0.00	0.00	0.00	7/06/05 5:52 AM	10/06/05 3:01 PM	186.63	0.00	0.00	0.00	186.63	164.17	0.00	0.00	0.00	164.17
22024	Gym	G	2380.87	2380.87	0.00	0.00	0.00	6/29/05 10:13 AM	10/06/05 3:04 PM	293.80	0.00	0.00	0.00	293.80	173.48	0.00	0.00	0.00	173.48

Normalized Data Logger Detail Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
21077	Classroom	CR	672	21.02	0.00	0.00	0.00	21.02	17.87	0.00	0.00	0.00	17.87	14.99%
20752	Classroom	CR	600	13.95	0.00	0.00	0.00	13.95	11.72	0.00	0.00	0.00	11.72	15.99%
21348	Hallway	H	600	56.17	0.00	0.00	0.00	56.17	21.28	0.00	0.00	0.00	21.28	62.12%
20807	Kitchen	K	521	11.61	0.00	0.00	0.00	11.61	4.70	0.00	0.00	0.00	4.70	59.52%
21764	Office	O	1150	44.01	0.00	0.00	0.00	44.01	38.25	0.00	0.00	0.00	38.25	13.09%
22368	Private Office	PO	120	14.14	0.00	0.00	0.00	14.14	12.44	0.00	0.00	0.00	12.44	12.02%
22024	Gym	G	6370	20.73	0.00	0.00	0.00	20.73	12.24	0.00	0.00	0.00	12.24	40.96%

Building Summary Totals Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Private Office		PO	1	120	2	0	0	2	1	0	0	0	1	
Hallway		H	1	600	34	0	0	34	13	0	0	0	13	
Classroom		CR	2	1272	22	0	0	22	19	0	0	0	19	
Gym		G	1	6370	132	0	0	132	78	0	0	0	78	
Kitchen		K	1	521	6	0	0	6	2	0	0	0	2	
Office		O	1	1150	51	0	0	51	44	0	0	0	44	
Building Totals				10033	246			0	246	157			0	157