


Area Type Averages

Building type:Health Club/Rec Facility. Building size:25K to less than 50K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	2	240	30.93	0.00	0.00	0.00	30.93	25.07	0.00	0.00	0.00	25.07	18.95%
Restroom	R	4	577	91.64	0.00	0.00	0.00	91.64	42.11	0.00	0.00	0.00	42.11	54.05%
Storage	S	2	128	45.13	0.00	0.00	0.00	45.13	17.60	0.00	0.00	0.00	17.60	61.00%
Hallway	H	5	576	102.34	0.00	0.00	0.00	102.34	48.37	0.00	0.00	0.00	48.37	52.74%
Classroom	CR	6	955	30.60	0.00	0.00	0.00	30.60	25.01	0.00	0.00	0.00	25.01	18.27%
Gym	G	2	1192	34.42	0.00	0.00	0.00	34.42	32.99	0.00	0.00	0.00	32.99	4.15%
Kitchen	K	2	768	37.52	0.00	0.00	0.00	37.52	30.89	0.00	0.00	0.00	30.89	17.67%
Copy Rm	C	2	240	78.56	0.00	0.00	0.00	78.56	41.24	0.00	0.00	0.00	41.24	47.51%
Library	LI	1	1488	45.08	0.00	0.00	0.00	45.08	42.73	0.00	0.00	0.00	42.73	5.21%
Office	O	1	384	65.40	0.00	0.00	0.00	65.40	39.18	0.00	0.00	0.00	39.18	40.09%
Open Office	OO	2	2016	99.46	0.00	0.00	0.00	99.46	41.48	0.00	0.00	0.00	41.48	58.29%
Conference	CN	3	1507	24.19	0.00	0.00	0.00	24.19	11.64	0.00	0.00	0.00	11.64	51.88%
General Office	GO	1	192	21.36	0.00	0.00	0.00	21.36	19.65	0.00	0.00	0.00	19.65	8.01%
Building Average			26671	55.94			0.00	55.94	31.66			0.00	31.66	43.40%



Hours per Week for each Area Type

Data Logger Detail Building type:Health Club/Rec Facility. Building size:25K to less than 50K. Shifts:2 Page 1 of 1

All Loggers Listed			Hours Installed							Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23386	Library	LI	323.58	323.58	0.00	0.00	0.00	10/10/05 12:26	10/24/05 12:00	86.83	0.00	0.00	0.00	86.83	82.30	0.00	0.00	0.00	82.30
21416	Open Office	OO	323.65	323.65	0.00	0.00	0.00	10/10/05 12:22	10/24/05 12:00	59.57	0.00	0.00	0.00	59.57	42.77	0.00	0.00	0.00	42.77
24368	Classroom	CR	322.18	322.18	0.00	0.00	0.00	10/10/05 1:50 PM	10/24/05 12:00	10.93	0.00	0.00	0.00	10.93	9.33	0.00	0.00	0.00	9.33
24053	Classroom	CR	325.27	325.27	0.00	0.00	0.00	10/10/05 10:45	10/24/05 12:00	87.23	0.00	0.00	0.00	87.23	82.90	0.00	0.00	0.00	82.90
23866	Gym	G	325.15	325.15	0.00	0.00	0.00	10/10/05 10:52	10/24/05 12:00	9.70	0.00	0.00	0.00	9.70	4.60	0.00	0.00	0.00	4.60
23536	General Office	GO	324.85	324.85	0.00	0.00	0.00	10/10/05 11:10	10/24/05 12:00	41.30	0.00	0.00	0.00	41.30	38.00	0.00	0.00	0.00	38.00
24045	Conference	CN	324.12	324.12	0.00	0.00	0.00	10/10/05 11:54	10/24/05 12:00	58.23	0.00	0.00	0.00	58.23	26.93	0.00	0.00	0.00	26.93
24360	Conference	CN	324.17	324.17	0.00	0.00	0.00	10/10/05 11:51	10/24/05 12:00	55.00	0.00	0.00	0.00	55.00	26.33	0.00	0.00	0.00	26.33
24052	Conference	CN	324.07	324.07	0.00	0.00	0.00	10/10/05 11:57	10/24/05 12:00	26.80	0.00	0.00	0.00	26.80	14.10	0.00	0.00	0.00	14.10
24060	Private Office	PO	324.82	324.82	0.00	0.00	0.00	10/10/05 11:12	10/24/05 12:00	103.73	0.00	0.00	0.00	103.73	83.20	0.00	0.00	0.00	83.20
24151	Classroom	CR	324.73	324.73	0.00	0.00	0.00	10/10/05 11:17	10/24/05 12:00	56.03	0.00	0.00	0.00	56.03	45.13	0.00	0.00	0.00	45.13
24006	Classroom	CR	323.45	323.45	0.00	0.00	0.00	10/10/05 12:34	10/24/05 12:00	52.33	0.00	0.00	0.00	52.33	38.23	0.00	0.00	0.00	38.23
22361	Storage	S	324.63	324.63	0.00	0.00	0.00	10/10/05 11:23	10/24/05 12:00	150.50	0.00	0.00	0.00	150.50	55.33	0.00	0.00	0.00	55.33
23807	Classroom	CR	324.58	324.58	0.00	0.00	0.00	10/10/05 11:26	10/24/05 12:00	74.10	0.00	0.00	0.00	74.10	60.17	0.00	0.00	0.00	60.17
23864	Classroom	CR	321.20	321.20	0.00	0.00	0.00	10/10/05 2:49 PM	10/24/05 12:00	73.27	0.00	0.00	0.00	73.27	53.53	0.00	0.00	0.00	53.53
23811	Gym	G	323.80	323.80	0.00	0.00	0.00	10/10/05 12:13	10/24/05 12:00	123.03	0.00	0.00	0.00	123.03	122.57	0.00	0.00	0.00	122.57
23648	Copy Rm	C	324.50	324.50	0.00	0.00	0.00	10/10/05 11:31	10/24/05 12:00	160.13	0.00	0.00	0.00	160.13	78.97	0.00	0.00	0.00	78.97
21933	Copy Rm	C	323.72	323.72	0.00	0.00	0.00	10/10/05 12:18	10/24/05 12:00	143.00	0.00	0.00	0.00	143.00	80.13	0.00	0.00	0.00	80.13
23622	Kitchen	K	323.95	323.95	0.00	0.00	0.00	10/10/05 12:04	10/24/05 12:00	88.83	0.00	0.00	0.00	88.83	64.17	0.00	0.00	0.00	64.17
23512	Hallway	H	324.78	324.78	0.00	0.00	0.00	10/10/05 11:14	10/24/05 12:00	324.78	0.00	0.00	0.00	324.78	94.80	0.00	0.00	0.00	94.80
24303	Hallway	H	324.15	324.15	0.00	0.00	0.00	10/10/05 11:52	10/24/05 12:00	117.67	0.00	0.00	0.00	117.67	107.27	0.00	0.00	0.00	107.27
24061	Hallway	H	324.03	324.03	0.00	0.00	0.00	10/10/05 11:59	10/24/05 12:00	324.03	0.00	0.00	0.00	324.03	102.70	0.00	0.00	0.00	102.70
24088	Hallway	H	324.00	324.00	0.00	0.00	0.00	10/10/05 12:01	10/24/05 12:00	96.20	0.00	0.00	0.00	96.20	89.83	0.00	0.00	0.00	89.83
23620	Hallway	H	324.33	324.33	0.00	0.00	0.00	10/10/05 11:41	10/24/05 12:00	125.18	0.00	0.00	0.00	125.18	72.18	0.00	0.00	0.00	72.18
24070	Kitchen	K	323.98	323.98	0.00	0.00	0.00	10/10/05 12:02	10/24/05 12:00	55.87	0.00	0.00	0.00	55.87	54.97	0.00	0.00	0.00	54.97
24035	Open Office	OO	323.70	323.70	0.00	0.00	0.00	10/10/05 12:19	10/24/05 12:00	323.70	0.00	0.00	0.00	323.70	117.07	0.00	0.00	0.00	117.07
24166	Restroom	R	325.48	325.48	0.00	0.00	0.00	10/10/05 10:32	10/24/05 12:00	156.93	0.00	0.00	0.00	156.93	84.33	0.00	0.00	0.00	84.33
23697	Restroom	R	325.08	325.08	0.00	0.00	0.00	10/10/05 10:56	10/24/05 12:00	113.40	0.00	0.00	0.00	113.40	59.90	0.00	0.00	0.00	59.90
23944	Private Office	PO	324.48	324.48	0.00	0.00	0.00	10/10/05 11:32	10/24/05 12:00	15.83	0.00	0.00	0.00	15.83	13.73	0.00	0.00	0.00	13.73
20837	Office	O	323.75	323.75	0.00	0.00	0.00	10/10/05 12:16	10/24/05 12:00	126.03	0.00	0.00	0.00	126.03	75.50	0.00	0.00	0.00	75.50
20592	Storage	S	318.77	318.77	0.00	0.00	0.00	10/10/05 5:15 PM	10/24/05 12:00	23.47	0.00	0.00	0.00	23.47	12.43	0.00	0.00	0.00	12.43
22857	Restroom	R	325.43	325.43	0.00	0.00	0.00	10/10/05 10:35	10/24/05 12:00	325.43	0.00	0.00	0.00	325.43	96.83	0.00	0.00	0.00	96.83
23581	Restroom	R	324.95	324.95	0.00	0.00	0.00	10/10/05 11:04	10/24/05 12:00	114.00	0.00	0.00	0.00	114.00	85.03	0.00	0.00	0.00	85.03

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23386	Library	LI	1488	45.08	0.00	0.00	0.00	45.08	42.73	0.00	0.00	0.00	42.73	5.21%
21416	Open Office	OO	768	30.92	0.00	0.00	0.00	30.92	22.20	0.00	0.00	0.00	22.20	28.20%
24368	Classroom	CR	960	5.70	0.00	0.00	0.00	5.70	4.87	0.00	0.00	0.00	4.87	14.56%
24053	Classroom	CR	960	45.06	0.00	0.00	0.00	45.06	42.82	0.00	0.00	0.00	42.82	4.97%
23866	Gym	G	384	5.01	0.00	0.00	0.00	5.01	2.38	0.00	0.00	0.00	2.38	52.50%
23536	General Office	GO	192	21.36	0.00	0.00	0.00	21.36	19.65	0.00	0.00	0.00	19.65	8.01%
24045	Conference	CN	1968	30.18	0.00	0.00	0.00	30.18	13.96	0.00	0.00	0.00	13.96	53.74%
24360	Conference	CN	1668	28.50	0.00	0.00	0.00	28.50	13.65	0.00	0.00	0.00	13.65	52.11%
24052	Conference	CN	884	13.89	0.00	0.00	0.00	13.89	7.31	0.00	0.00	0.00	7.31	47.37%
24060	Private Office	PO	288	53.65	0.00	0.00	0.00	53.65	43.03	0.00	0.00	0.00	43.03	19.79%
24151	Classroom	CR	1024	28.99	0.00	0.00	0.00	28.99	23.35	0.00	0.00	0.00	23.35	19.45%
24006	Classroom	CR	768	27.18	0.00	0.00	0.00	27.18	19.86	0.00	0.00	0.00	19.86	26.93%
22361	Storage	S	192	77.88	0.00	0.00	0.00	77.88	28.64	0.00	0.00	0.00	28.64	63.23%
23807	Classroom	CR	1152	38.35	0.00	0.00	0.00	38.35	31.14	0.00	0.00	0.00	31.14	18.80%
23864	Classroom	CR	864	38.32	0.00	0.00	0.00	38.32	28.00	0.00	0.00	0.00	28.00	26.93%
23811	Gym	G	2000	63.83	0.00	0.00	0.00	63.83	63.59	0.00	0.00	0.00	63.59	0.38%
23648	Copy Rm	C	288	82.90	0.00	0.00	0.00	82.90	40.88	0.00	0.00	0.00	40.88	50.69%
21933	Copy Rm	C	192	74.21	0.00	0.00	0.00	74.21	41.59	0.00	0.00	0.00	41.59	43.96%
23622	Kitchen	K	576	46.07	0.00	0.00	0.00	46.07	33.28	0.00	0.00	0.00	33.28	27.76%
23512	Hallway	H	672	168.00	0.00	0.00	0.00	168.00	49.04	0.00	0.00	0.00	49.04	70.81%
24303	Hallway	H	288	60.98	0.00	0.00	0.00	60.98	55.59	0.00	0.00	0.00	55.59	8.84%
24061	Hallway	H	384	168.00	0.00	0.00	0.00	168.00	53.25	0.00	0.00	0.00	53.25	68.30%
24088	Hallway	H	960	49.88	0.00	0.00	0.00	49.88	46.58	0.00	0.00	0.00	46.58	6.62%
23620	Hallway	H	576	64.84	0.00	0.00	0.00	64.84	37.39	0.00	0.00	0.00	37.39	42.33%
24070	Kitchen	K	960	28.97	0.00	0.00	0.00	28.97	28.50	0.00	0.00	0.00	28.50	1.62%
24035	Open Office	OO	3264	168.00	0.00	0.00	0.00	168.00	60.76	0.00	0.00	0.00	60.76	63.83%
24166	Restroom	R	580	81.00	0.00	0.00	0.00	81.00	43.53	0.00	0.00	0.00	43.53	46.26%
23697	Restroom	R	452	58.60	0.00	0.00	0.00	58.60	30.96	0.00	0.00	0.00	30.96	47.17%
23944	Private Office	PO	192	8.20	0.00	0.00	0.00	8.20	7.11	0.00	0.00	0.00	7.11	13.29%
20837	Office	O	384	65.40	0.00	0.00	0.00	65.40	39.18	0.00	0.00	0.00	39.18	40.09%
20592	Storage	S	64	12.37	0.00	0.00	0.00	12.37	6.55	0.00	0.00	0.00	6.55	47.05%
22857	Restroom	R	696	168.00	0.00	0.00	0.00	168.00	49.99	0.00	0.00	0.00	49.99	70.24%
23581	Restroom	R	580	58.94	0.00	0.00	0.00	58.94	43.96	0.00	0.00	0.00	43.96	25.42%

Building Summary Totals Building type:Health Club/Rec Facility. Building size:25K to less than 50K. Shifts:2 Page 1 of 1

Building Summary Totals			Lights On KWHR						Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	2	480	15	0	0	0	15	12	0	0	0	12
Restroom	R	4	2308	212	0	0	0	212	97	0	0	0	97
Storage	S	2	256	12	0	0	0	12	5	0	0	0	5
Hallway	H	5	2880	295	0	0	0	295	139	0	0	0	139
Classroom	CR	6	5730	175	0	0	0	175	143	0	0	0	143
Gym	G	2	2384	82	0	0	0	82	79	0	0	0	79
Kitchen	K	2	1536	58	0	0	0	58	47	0	0	0	47
Copy Rm	C	2	480	38	0	0	0	38	20	0	0	0	20
Library	LI	1	1488	67	0	0	0	67	64	0	0	0	64
Office	O	1	384	25	0	0	0	25	15	0	0	0	15
Open Office	OO	2	4032	401	0	0	0	401	167	0	0	0	167
Conference	CN	3	4521	109	0	0	0	109	53	0	0	0	53
General Office	GO	1	192	4	0	0	0	4	4	0	0	0	4
Building Totals			26671	1492			0	1492	845			0	845