


Area Type Averages

Building type:High School. Building size:100K to less than 250K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	4	290	53.36	0.00	0.00	0.00	53.36	47.19	0.00	0.00	0.00	47.19	11.56%
Meeting Rooms	M	1	360	49.67	0.00	0.00	0.00	49.67	40.18	0.00	0.00	0.00	40.18	19.11%
Open Space	OS	2	800	49.72	0.00	0.00	0.00	49.72	43.31	0.00	0.00	0.00	43.31	12.89%
Storage	S	1	320	45.17	0.00	0.00	0.00	45.17	0.49	0.00	0.00	0.00	0.49	98.92%
Hallway	H	10	541	98.45	0.00	0.00	0.00	98.45	53.24	0.00	0.00	0.00	53.24	45.92%
Classroom	CR	12	1127	38.45	0.00	0.00	0.00	38.45	30.37	0.00	0.00	0.00	30.37	21.01%
Kitchen	K	1	1068	63.09	0.00	0.00	0.00	63.09	31.60	0.00	0.00	0.00	31.60	49.91%
Locker Room	LR	1	1140	93.79	0.00	0.00	0.00	93.79	35.55	0.00	0.00	0.00	35.55	62.10%
Cafeteria	CF	2	1602	39.84	0.00	0.00	0.00	39.84	36.88	0.00	0.00	0.00	36.88	7.43%
Library	LI	2	2759	52.29	0.00	0.00	0.00	52.29	42.46	0.00	0.00	0.00	42.46	18.80%
Building Average			33304	54.55			0.00	54.55	37.96			0.00	37.96	30.41%



Hours per Week for each Area Type

Data Logger Detail Building type:High School. Building size:100K to less than 250K. Shifts:2 Page 1 of 1

All Loggers Listed			Hours Installed					Installed		Removed		Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total		
24071	Classroom	CR	386.72	386.72	0.00	0.00	0.00	9/26/05 12:52 PM	10/12/05 3:34 PM	79.30	0.00	0.00	0.00	79.30	67.03	0.00	0.00	0.00	67.03		
21571	Classroom	CR	386.53	386.53	0.00	0.00	0.00	9/26/05 1:02 PM	10/12/05 3:33 PM	69.98	0.00	0.00	0.00	69.98	58.62	0.00	0.00	0.00	58.62		
21984	Classroom	CR	386.72	386.72	0.00	0.00	0.00	9/26/05 12:50 PM	10/12/05 3:32 PM	136.43	0.00	0.00	0.00	136.43	80.37	0.00	0.00	0.00	80.37		
21898	Classroom	CR	386.63	386.63	0.00	0.00	0.00	9/26/05 12:52 PM	10/12/05 3:29 PM	112.42	0.00	0.00	0.00	112.42	73.93	0.00	0.00	0.00	73.93		
21801	Classroom	CR	386.55	386.55	0.00	0.00	0.00	9/26/05 12:54 PM	10/12/05 3:26 PM	113.43	0.00	0.00	0.00	113.43	97.07	0.00	0.00	0.00	97.07		
20119	Classroom	CR	655.70	655.70	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:41 PM	102.25	0.00	0.00	0.00	102.25	64.90	0.00	0.00	0.00	64.90		
20308	Classroom	CR	679.40	679.40	0.00	0.00	0.00	9/15/05 8:00 AM	10/13/05 3:23 PM	160.22	0.00	0.00	0.00	160.22	150.82	0.00	0.00	0.00	150.82		
20427	Classroom	CR	651.13	651.13	0.00	0.00	0.00	9/15/05 12:36 PM	10/12/05 3:43 PM	30.77	0.00	0.00	0.00	30.77	26.93	0.00	0.00	0.00	26.93		
20053	Classroom	CR	679.42	679.42	0.00	0.00	0.00	9/15/05 8:00 AM	10/13/05 3:24 PM	128.27	0.00	0.00	0.00	128.27	100.53	0.00	0.00	0.00	100.53		
20375	Cafeteria	CF	684.02	684.02	0.00	0.00	0.00	9/15/05 8:00 AM	10/13/05 8:00 PM	158.72	0.00	0.00	0.00	158.72	137.88	0.00	0.00	0.00	137.88		
20433	Cafeteria	CF	655.08	655.08	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:04 PM	158.67	0.00	0.00	0.00	158.67	155.50	0.00	0.00	0.00	155.50		
21713	Hallway	H	386.75	386.75	0.00	0.00	0.00	9/26/05 12:50 PM	10/12/05 3:34 PM	143.58	0.00	0.00	0.00	143.58	86.95	0.00	0.00	0.00	86.95		
20470	Hallway	H	655.40	655.40	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:23 PM	266.73	0.00	0.00	0.00	266.73	222.03	0.00	0.00	0.00	222.03		
23809	Hallway	H	386.52	386.52	0.00	0.00	0.00	9/26/05 12:48 PM	10/12/05 3:18 PM	386.50	0.00	0.00	0.00	386.50	133.50	0.00	0.00	0.00	133.50		
20174	Hallway	H	655.27	655.27	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:15 PM	329.62	0.00	0.00	0.00	329.62	222.47	0.00	0.00	0.00	222.47		
20211	Hallway	H	655.43	655.43	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:25 PM	265.63	0.00	0.00	0.00	265.63	219.37	0.00	0.00	0.00	219.37		
20670	Hallway	H	386.67	386.67	0.00	0.00	0.00	9/26/05 12:26 PM	10/12/05 3:05 PM	168.25	0.00	0.00	0.00	168.25	133.22	0.00	0.00	0.00	133.22		
20181	Hallway	H	655.33	655.33	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:19 PM	241.02	0.00	0.00	0.00	241.02	110.43	0.00	0.00	0.00	110.43		
22655	Hallway	H	387.32	387.32	0.00	0.00	0.00	9/26/05 12:18 PM	10/12/05 3:36 PM	143.53	0.00	0.00	0.00	143.53	110.87	0.00	0.00	0.00	110.87		
20468	Kitchen	K	655.17	655.17	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:09 PM	246.03	0.00	0.00	0.00	246.03	123.25	0.00	0.00	0.00	123.25		
20107	Library	LI	655.65	655.65	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:38 PM	204.07	0.00	0.00	0.00	204.07	163.10	0.00	0.00	0.00	163.10		
20134	Library	LI	655.65	655.65	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:38 PM	204.03	0.00	0.00	0.00	204.03	168.27	0.00	0.00	0.00	168.27		
20362	Private Office	PO	655.72	655.72	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:42 PM	190.03	0.00	0.00	0.00	190.03	187.97	0.00	0.00	0.00	187.97		
20350	Open Space	OS	655.58	655.58	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:34 PM	191.43	0.00	0.00	0.00	191.43	143.77	0.00	0.00	0.00	143.77		
22621	Hallway	H	387.32	387.32	0.00	0.00	0.00	9/26/05 12:21 PM	10/12/05 3:39 PM	387.30	0.00	0.00	0.00	387.30	157.47	0.00	0.00	0.00	157.47		
22673	Open Space	OS	387.37	387.37	0.00	0.00	0.00	9/26/05 12:17 PM	10/12/05 3:38 PM	116.15	0.00	0.00	0.00	116.15	114.75	0.00	0.00	0.00	114.75		
21523	Hallway	H	386.60	386.60	0.00	0.00	0.00	9/26/05 12:26 PM	10/12/05 3:01 PM	386.58	0.00	0.00	0.00	386.58	146.85	0.00	0.00	0.00	146.85		
20346	Private Office	PO	655.10	655.10	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:05 PM	219.03	0.00	0.00	0.00	219.03	194.73	0.00	0.00	0.00	194.73		
20347	Locker Room	LR	655.80	655.80	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:47 PM	366.10	0.00	0.00	0.00	366.10	138.78	0.00	0.00	0.00	138.78		
20307	Private Office	PO	655.75	655.75	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:44 PM	153.98	0.00	0.00	0.00	153.98	146.65	0.00	0.00	0.00	146.65		
20038	Meeting Rooms	M	655.67	655.67	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:39 PM	193.87	0.00	0.00	0.00	193.87	156.82	0.00	0.00	0.00	156.82		
20481	Classroom	CR	386.52	386.52	0.00	0.00	0.00	9/26/05 12:44 PM	10/12/05 3:14 PM	102.47	0.00	0.00	0.00	102.47	99.10	0.00	0.00	0.00	99.10		
20029	Classroom	CR	655.13	655.13	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:07 PM	192.55	0.00	0.00	0.00	192.55	167.45	0.00	0.00	0.00	167.45		
20074	Private Office	PO	655.63	655.63	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:37 PM	269.78	0.00	0.00	0.00	269.78	207.18	0.00	0.00	0.00	207.18		
22529	Classroom	CR	386.55	386.55	0.00	0.00	0.00	9/26/05 12:44 PM	10/12/05 3:16 PM	91.47	0.00	0.00	0.00	91.47	66.43	0.00	0.00	0.00	66.43		
20327	Storage	S	655.83	655.83	0.00	0.00	0.00	9/15/05 8:00 AM	10/12/05 3:49 PM	176.32	0.00	0.00	0.00	176.32	1.90	0.00	0.00	0.00	1.90		

Normalized Data Logger Detail Building type:High School. Building size:100K to less than 250K. Shifts:2 Page 1 of 1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24071	Classroom	CR	801	34.45	0.00	0.00	0.00	34.45	29.12	0.00	0.00	0.00	29.12	15.47%
21571	Classroom	CR	801	30.42	0.00	0.00	0.00	30.42	25.48	0.00	0.00	0.00	25.48	16.24%
21984	Classroom	CR	801	59.27	0.00	0.00	0.00	59.27	34.91	0.00	0.00	0.00	34.91	41.10%
21898	Classroom	CR	801	48.85	0.00	0.00	0.00	48.85	32.13	0.00	0.00	0.00	32.13	34.23%
21801	Classroom	CR	1335	49.30	0.00	0.00	0.00	49.30	42.19	0.00	0.00	0.00	42.19	14.42%
20119	Classroom	CR	1780	26.20	0.00	0.00	0.00	26.20	16.63	0.00	0.00	0.00	16.63	36.53%
20308	Classroom	CR	1602	39.62	0.00	0.00	0.00	39.62	37.29	0.00	0.00	0.00	37.29	5.88%
20427	Classroom	CR	1958	7.94	0.00	0.00	0.00	7.94	6.95	0.00	0.00	0.00	6.95	12.47%
20053	Classroom	CR	640	31.72	0.00	0.00	0.00	31.72	24.86	0.00	0.00	0.00	24.86	21.63%
20375	Cafeteria	CF	1602	38.98	0.00	0.00	0.00	38.98	33.87	0.00	0.00	0.00	33.87	13.11%
20433	Cafeteria	CF	1602	40.69	0.00	0.00	0.00	40.69	39.88	0.00	0.00	0.00	39.88	1.99%
21713	Hallway	H	120	62.37	0.00	0.00	0.00	62.37	37.77	0.00	0.00	0.00	37.77	39.44%
20470	Hallway	H	420	68.37	0.00	0.00	0.00	68.37	56.91	0.00	0.00	0.00	56.91	16.76%
23809	Hallway	H	178	167.99	0.00	0.00	0.00	167.99	58.03	0.00	0.00	0.00	58.03	65.46%
20174	Hallway	H	1080	84.51	0.00	0.00	0.00	84.51	57.04	0.00	0.00	0.00	57.04	32.51%
20211	Hallway	H	720	68.09	0.00	0.00	0.00	68.09	56.23	0.00	0.00	0.00	56.23	17.42%
20670	Hallway	H	1335	73.10	0.00	0.00	0.00	73.10	57.88	0.00	0.00	0.00	57.88	20.82%
20181	Hallway	H	178	61.79	0.00	0.00	0.00	61.79	28.31	0.00	0.00	0.00	28.31	54.18%
22655	Hallway	H	180	62.26	0.00	0.00	0.00	62.26	48.09	0.00	0.00	0.00	48.09	22.76%
20468	Kitchen	K	1068	63.09	0.00	0.00	0.00	63.09	31.60	0.00	0.00	0.00	31.60	49.91%
20107	Library	LI	2670	52.29	0.00	0.00	0.00	52.29	41.79	0.00	0.00	0.00	41.79	20.08%
20134	Library	LI	2848	52.28	0.00	0.00	0.00	52.28	43.12	0.00	0.00	0.00	43.12	17.52%
20362	Private Office	PO	240	48.69	0.00	0.00	0.00	48.69	48.16	0.00	0.00	0.00	48.16	1.09%
20350	Open Space	OS	640	49.06	0.00	0.00	0.00	49.06	36.84	0.00	0.00	0.00	36.84	24.91%
22621	Hallway	H	840	167.99	0.00	0.00	0.00	167.99	68.30	0.00	0.00	0.00	68.30	59.34%
22673	Open Space	OS	960	50.37	0.00	0.00	0.00	50.37	49.77	0.00	0.00	0.00	49.77	1.19%
21523	Hallway	H	356	167.99	0.00	0.00	0.00	167.99	63.81	0.00	0.00	0.00	63.81	62.02%
20346	Private Office	PO	178	56.17	0.00	0.00	0.00	56.17	49.94	0.00	0.00	0.00	49.94	11.09%
20347	Locker Room	LR	1140	93.79	0.00	0.00	0.00	93.79	35.55	0.00	0.00	0.00	35.55	62.10%
20307	Private Office	PO	560	39.45	0.00	0.00	0.00	39.45	37.57	0.00	0.00	0.00	37.57	4.77%
20038	Meeting Rooms	M	360	49.67	0.00	0.00	0.00	49.67	40.18	0.00	0.00	0.00	40.18	19.11%
20481	Classroom	CR	801	44.54	0.00	0.00	0.00	44.54	43.07	0.00	0.00	0.00	43.07	3.30%
20029	Classroom	CR	1068	49.38	0.00	0.00	0.00	49.38	42.94	0.00	0.00	0.00	42.94	13.04%
20074	Private Office	PO	180	69.13	0.00	0.00	0.00	69.13	53.09	0.00	0.00	0.00	53.09	23.20%
22529	Classroom	CR	1140	39.75	0.00	0.00	0.00	39.75	28.87	0.00	0.00	0.00	28.87	27.37%
20327	Storage	S	320	45.17	0.00	0.00	0.00	45.17	0.49	0.00	0.00	0.00	0.49	98.92%

Building Summary Totals Building type:High School. Building size:100K to less than 250K. Shifts:2 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	4	1160	62	0	0	0	62	55	0	0	0	55
Meeting Rooms	M	1	360	18	0	0	0	18	14	0	0	0	14
Open Space	OS	2	1600	80	0	0	0	80	69	0	0	0	69
Storage	S	1	320	14	0	0	0	14	0	0	0	0	0
Hallway	H	10	5410	533	0	0	0	533	288	0	0	0	288
Classroom	CR	12	13524	520	0	0	0	520	411	0	0	0	411
Kitchen	K	1	1068	67	0	0	0	67	34	0	0	0	34
Locker Room	LR	1	1140	107	0	0	0	107	41	0	0	0	41
Cafeteria	CF	2	3204	128	0	0	0	128	118	0	0	0	118
Library	LI	2	5518	289	0	0	0	289	234	0	0	0	234
Building Totals			33304	1817			0	1817	1264			0	1264