


# Area Type Averages

Building type:High School. Building size:25K to less than 50K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Hallway	H	1	400	81.72	0.00	0.00	0.00	81.72	51.23	0.00	0.00	0.00	51.23	37.31%
Classroom	CR	8	920	51.97	0.00	0.00	0.00	51.97	28.66	0.00	0.00	0.00	28.66	44.85%
Office	O	1	960	29.47	0.00	0.00	0.00	29.47	24.53	0.00	0.00	0.00	24.53	16.76%
Computer Room	CP	1	1200	38.87	0.00	0.00	0.00	38.87	35.29	0.00	0.00	0.00	35.29	9.21%
Building Average			9920	49.41			0.00	49.41	29.97			0.00	29.97	39.34%



**Hours per Week for each Area Type**

# Data Logger Detail Building type:High School. Building size:25K to less than 50K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23907	Office	O	501.53	501.53	0.00	0.00	0.00	10/07/05 4:29 AM	10/28/05 2:00 AM	87.97	0.00	0.00	0.00	87.97	73.23	0.00	0.00	0.00	73.23
23621	Classroom	CR	492.73	492.73	0.00	0.00	0.00	10/07/05 1:17 PM	10/28/05 2:00 AM	92.13	0.00	0.00	0.00	92.13	87.10	0.00	0.00	0.00	87.10
23884	Classroom	CR	505.55	505.55	0.00	0.00	0.00	10/06/05 8:28 PM	10/27/05 10:00	133.90	0.00	0.00	0.00	133.90	90.30	0.00	0.00	0.00	90.30
24171	Computer Room	CP	494.27	494.27	0.00	0.00	0.00	10/07/05 11:45	10/28/05 2:00 AM	114.37	0.00	0.00	0.00	114.37	103.83	0.00	0.00	0.00	103.83
23766	Hallway	H	505.50	505.50	0.00	0.00	0.00	10/06/05 8:31 PM	10/27/05 10:00	245.90	0.00	0.00	0.00	245.90	154.13	0.00	0.00	0.00	154.13
24203	Classroom	CR	494.32	494.32	0.00	0.00	0.00	10/07/05 11:42	10/28/05 2:00 AM	94.50	0.00	0.00	0.00	94.50	82.43	0.00	0.00	0.00	82.43
23804	Classroom	CR	494.47	494.47	0.00	0.00	0.00	10/07/05 7:33 AM	10/27/05 10:00	116.07	0.00	0.00	0.00	116.07	91.67	0.00	0.00	0.00	91.67
21554	Classroom	CR	494.45	494.45	0.00	0.00	0.00	10/07/05 11:34	10/28/05 2:00 AM	72.80	0.00	0.00	0.00	72.80	49.73	0.00	0.00	0.00	49.73
24120	Classroom	CR	494.28	494.28	0.00	0.00	0.00	10/07/05 7:44 AM	10/27/05 10:00	103.18	0.00	0.00	0.00	103.18	99.82	0.00	0.00	0.00	99.82
23874	Classroom	CR	495.07	495.07	0.00	0.00	0.00	10/07/05 6:57 AM	10/27/05 10:00	119.20	0.00	0.00	0.00	119.20	91.47	0.00	0.00	0.00	91.47
23200	Classroom	CR	505.45	505.45	0.00	0.00	0.00	10/06/05 8:34 PM	10/27/05 10:00	505.45	0.00	0.00	0.00	505.45	85.77	0.00	0.00	0.00	85.77

## Normalized Data Logger Detail Building type:High School. Building size:25K to less than 50K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23907	Office	O	960	29.47	0.00	0.00	0.00	29.47	24.53	0.00	0.00	0.00	24.53	16.76%
23621	Classroom	CR	1440	31.41	0.00	0.00	0.00	31.41	29.70	0.00	0.00	0.00	29.70	5.44%
23884	Classroom	CR	960	44.50	0.00	0.00	0.00	44.50	30.01	0.00	0.00	0.00	30.01	32.56%
24171	Computer	CP	1200	38.87	0.00	0.00	0.00	38.87	35.29	0.00	0.00	0.00	35.29	9.21%
23766	Hallway	H	400	81.72	0.00	0.00	0.00	81.72	51.23	0.00	0.00	0.00	51.23	37.31%
24203	Classroom	CR	960	32.12	0.00	0.00	0.00	32.12	28.02	0.00	0.00	0.00	28.02	12.76%
23804	Classroom	CR	720	39.43	0.00	0.00	0.00	39.43	31.14	0.00	0.00	0.00	31.14	21.02%
21554	Classroom	CR	720	24.74	0.00	0.00	0.00	24.74	16.90	0.00	0.00	0.00	16.90	31.69%
24120	Classroom	CR	1280	35.07	0.00	0.00	0.00	35.07	33.93	0.00	0.00	0.00	33.93	3.25%
23874	Classroom	CR	960	40.45	0.00	0.00	0.00	40.45	31.04	0.00	0.00	0.00	31.04	23.26%
23200	Classroom	CR	320	168.00	0.00	0.00	0.00	168.00	28.51	0.00	0.00	0.00	28.51	83.03%

## Building Summary Totals Building type:High School. Building size:25K to less than 50K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Hallway	H	1	400	33	0	0	33	20	0	0	0	20	
Classroom	CR	8	7360	382	0	0	382	211	0	0	0	211	
Office	O	1	960	28	0	0	28	24	0	0	0	24	
Computer Room	CP	1	1200	47	0	0	47	42	0	0	0	42	
Building Totals			9920	490	0			490	297	0			297