


Area Type Averages

Building type:High School. Building size:50K to less than 100K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Restroom	R	1	480	53.14	0.00	0.00	0.00	53.14	35.92	0.00	0.00	0.00	35.92	32.40%
Classroom	CR	2	2050	27.12	0.00	0.00	0.00	27.12	25.37	0.00	0.00	0.00	25.37	6.45%
Locker Room	LR	7	574	90.65	0.00	0.00	0.00	90.65	48.27	0.00	0.00	0.00	48.27	46.75%
Cafeteria	CF	1	780	43.49	0.00	0.00	0.00	43.49	41.59	0.00	0.00	0.00	41.59	4.37%
FAB Shop	F	2	2100	47.39	0.00	0.00	0.00	47.39	34.09	0.00	0.00	0.00	34.09	28.06%
Building Average			13578	54.05			0.00	54.05	36.15			0.00	36.15	33.12%



Hours per Week for each Area Type

Data Logger Detail Building type:High School. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20672	Cafeteria	CF	347.93	347.93	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:55	90.07	0.00	0.00	0.00	90.07	86.13	0.00	0.00	0.00	86.13
21684	FAB Shop	F	347.08	347.08	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:04	79.18	0.00	0.00	0.00	79.18	50.75	0.00	0.00	0.00	50.75
21063	Classroom	CR	347.15	347.15	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:08	102.30	0.00	0.00	0.00	102.30	96.67	0.00	0.00	0.00	96.67
24300	Locker Room	LR	348.00	348.00	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:59	198.12	0.00	0.00	0.00	198.12	81.18	0.00	0.00	0.00	81.18
23851	Locker Room	LR	347.67	347.67	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:39	161.02	0.00	0.00	0.00	161.02	112.02	0.00	0.00	0.00	112.02
24369	Locker Room	LR	347.70	347.70	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:41	204.52	0.00	0.00	0.00	204.52	111.78	0.00	0.00	0.00	111.78
22980	Locker Room	LR	347.80	347.80	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:47	122.80	0.00	0.00	0.00	122.80	105.57	0.00	0.00	0.00	105.57
23498	Locker Room	LR	347.85	347.85	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:50	138.40	0.00	0.00	0.00	138.40	115.27	0.00	0.00	0.00	115.27
24131	Locker Room	LR	347.87	347.87	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:51	141.03	0.00	0.00	0.00	141.03	87.03	0.00	0.00	0.00	87.03
20905	FAB Shop	F	347.03	347.03	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:01	116.58	0.00	0.00	0.00	116.58	90.10	0.00	0.00	0.00	90.10
22873	Restroom	R	347.33	347.33	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:19	109.87	0.00	0.00	0.00	109.87	74.27	0.00	0.00	0.00	74.27
23845	Locker Room	LR	347.22	347.22	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:12	347.20	0.00	0.00	0.00	347.20	86.53	0.00	0.00	0.00	86.53
20667	Classroom	CR	347.50	347.50	0.00	0.00	0.00	9/22/05 11:00 PM	10/07/05 10:29	9.77	0.00	0.00	0.00	9.77	8.17	0.00	0.00	0.00	8.17

Normalized Data Logger Detail Building type:High School. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20672	Cafeteria	CF	780	43.49	0.00	0.00	0.00	43.49	41.59	0.00	0.00	0.00	41.59	4.37%
21684	FAB Shop	F	2880	38.33	0.00	0.00	0.00	38.33	24.56	0.00	0.00	0.00	24.56	35.92%
21063	Classroom	CR	2700	49.51	0.00	0.00	0.00	49.51	46.78	0.00	0.00	0.00	46.78	5.51%
24300	Locker Room	LR	240	95.64	0.00	0.00	0.00	95.64	39.19	0.00	0.00	0.00	39.19	59.02%
23851	Locker Room	LR	660	77.81	0.00	0.00	0.00	77.81	54.13	0.00	0.00	0.00	54.13	30.43%
24369	Locker Room	LR	360	98.82	0.00	0.00	0.00	98.82	54.01	0.00	0.00	0.00	54.01	45.35%
22980	Locker Room	LR	780	59.32	0.00	0.00	0.00	59.32	50.99	0.00	0.00	0.00	50.99	14.04%
23498	Locker Room	LR	360	66.84	0.00	0.00	0.00	66.84	55.67	0.00	0.00	0.00	55.67	16.71%
24131	Locker Room	LR	780	68.11	0.00	0.00	0.00	68.11	42.03	0.00	0.00	0.00	42.03	38.29%
20905	FAB Shop	F	1320	56.44	0.00	0.00	0.00	56.44	43.62	0.00	0.00	0.00	43.62	22.71%
22873	Restroom	R	480	53.14	0.00	0.00	0.00	53.14	35.92	0.00	0.00	0.00	35.92	32.40%
23845	Locker Room	LR	840	167.99	0.00	0.00	0.00	167.99	41.87	0.00	0.00	0.00	41.87	75.08%
20667	Classroom	CR	1400	4.72	0.00	0.00	0.00	4.72	3.95	0.00	0.00	0.00	3.95	16.31%

Building Summary Totals Building type:High School. Building size:50K to less than 100K. Shifts:2

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	1	480	26	0	0	0	26	17	0	0	0	17
Classroom	CR	2	4100	111	0	0	0	111	104	0	0	0	104
Locker Room	LR	7	4018	364	0	0	0	364	194	0	0	0	194
Cafeteria	CF	1	780	34	0	0	0	34	32	0	0	0	32
FAB Shop	F	2	4200	199	0	0	0	199	143	0	0	0	143
Building Totals			13578	734		0	0	734	491			0	491