


Area Type Averages

Building type:Hotel/Casino. Building size:100K to less than 250K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Private Office	PO	1	100	143.60	0.00	0.00	0.00	143.60	95.88	0.00	0.00	0.00	95.88	33.23%
Restroom	R	1	100	166.79	0.00	0.00	0.00	166.79	88.19	0.00	0.00	0.00	88.19	47.13%
Locker Room	LR	1	100	167.99	0.00	0.00	0.00	167.99	135.13	0.00	0.00	0.00	135.13	19.56%
Copy Rm	C	1	100	49.79	0.00	0.00	0.00	49.79	19.36	0.00	0.00	0.00	19.36	61.12%
Office	O	2	100	61.73	0.00	0.00	0.00	61.73	47.16	0.00	0.00	0.00	47.16	23.60%
Building Average			600	108.61			0.00	108.61	72.15			0.00	72.15	33.57%



Hours per Week for each Area Type

Data Logger Detail Building type:Hotel/Casino. Building size:100K to less than 250K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
24299	Office	O	454.90	454.90	0.00	0.00	0.00	10/26/05 12:22	11/14/05 11:15	185.42	0.00	0.00	0.00	185.42	170.98	0.00	0.00	0.00	170.98
23937	Locker Room	LR	455.02	455.02	0.00	0.00	0.00	10/26/05 12:16	11/14/05 11:16	455.00	0.00	0.00	0.00	455.00	366.00	0.00	0.00	0.00	366.00
23423	Copy Rm	C	455.03	455.03	0.00	0.00	0.00	10/26/05 12:08	11/14/05 11:09	134.85	0.00	0.00	0.00	134.85	52.43	0.00	0.00	0.00	52.43
21970	Office	O	455.03	455.03	0.00	0.00	0.00	10/26/05 12:09	11/14/05 11:10	148.90	0.00	0.00	0.00	148.90	84.40	0.00	0.00	0.00	84.40
22845	Private Office	PO	454.93	454.93	0.00	0.00	0.00	10/26/05 12:23	11/14/05 11:18	388.85	0.00	0.00	0.00	388.85	259.63	0.00	0.00	0.00	259.63
23959	Restroom	R	454.80	454.80	0.00	0.00	0.00	10/26/05 12:25	11/14/05 11:12	451.52	0.00	0.00	0.00	451.52	238.73	0.00	0.00	0.00	238.73

Normalized Data Logger Detail Building type:Hotel/Casino. Building size:100K to less than 250K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24299	Office	O	100	68.48	0.00	0.00	0.00	68.48	63.15	0.00	0.00	0.00	63.15	7.78%
23937	Locker Room	LR	100	167.99	0.00	0.00	0.00	167.99	135.13	0.00	0.00	0.00	135.13	19.56%
23423	Copy Rm	C	100	49.79	0.00	0.00	0.00	49.79	19.36	0.00	0.00	0.00	19.36	61.12%
21970	Office	O	100	54.97	0.00	0.00	0.00	54.97	31.16	0.00	0.00	0.00	31.16	43.31%
22845	Private Office	PO	100	143.60	0.00	0.00	0.00	143.60	95.88	0.00	0.00	0.00	95.88	33.23%
23959	Restroom	R	100	166.79	0.00	0.00	0.00	166.79	88.19	0.00	0.00	0.00	88.19	47.13%

Building Summary Totals Building type:Hotel/Casino. Building size:100K to less than 250K. Shifts:1

Building Summary Totals				Lights On KwHR					Occupied KwHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office		PO	1	100	14	0	0	14	10	0	0	0	10
Restroom		R	1	100	17	0	0	17	9	0	0	0	9
Locker Room		LR	1	100	17	0	0	17	14	0	0	0	14
Copy Rm		C	1	100	5	0	0	5	2	0	0	0	2
Office		O	2	200	12	0	0	12	9	0	0	0	9
Building Totals				600	65		0	65	43		0		43