


Area Type Averages

Building type:Industrial Manufacturing. Building size:more than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Mechanical Room /	MR	12	5363	137.37	0.00	0.00	0.00	137.37	78.01	0.00	0.00	0.00	78.01	43.21%
Building Average			64356	137.37			0.00	137.37	78.01			0.00	78.01	43.21%



Hours per Week for each Area Type

Data Logger Detail Building type:Industrial Manufacturing. Building size:more than 1,000K. Shifts:3

All Loggers Listed			Hours Installed						Lights On					Occupied					
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20643	Mechanical Room / Storage	MR	320.27	320.27	0.00	0.00	0.00	11/09/05 3:45 PM	11/23/05 12:00	234.17	0.00	0.00	0.00	234.17	226.87	0.00	0.00	0.00	226.87
23631	Mechanical Room / Storage	MR	320.38	320.38	0.00	0.00	0.00	11/09/05 3:38 PM	11/23/05 12:00	233.75	0.00	0.00	0.00	233.75	201.92	0.00	0.00	0.00	201.92
23680	Mechanical Room / Storage	MR	320.32	320.32	0.00	0.00	0.00	11/09/05 3:42 PM	11/23/05 12:00	320.32	0.00	0.00	0.00	320.32	79.83	0.00	0.00	0.00	79.83
23582	Mechanical Room / Storage	MR	320.37	320.37	0.00	0.00	0.00	11/09/05 3:39 PM	11/23/05 12:00	210.07	0.00	0.00	0.00	210.07	206.37	0.00	0.00	0.00	206.37
23543	Mechanical Room / Storage	MR	321.32	321.32	0.00	0.00	0.00	11/09/05 2:42 PM	11/23/05 12:00	211.57	0.00	0.00	0.00	211.57	71.77	0.00	0.00	0.00	71.77
23303	Mechanical Room / Storage	MR	178.07	178.07	0.00	0.00	0.00	11/09/05 2:29 PM	11/17/05 12:32	178.05	0.00	0.00	0.00	178.05	71.47	0.00	0.00	0.00	71.47
23638	Mechanical Room / Storage	MR	321.45	321.45	0.00	0.00	0.00	11/09/05 2:34 PM	11/23/05 12:00	321.45	0.00	0.00	0.00	321.45	229.05	0.00	0.00	0.00	229.05
22699	Mechanical Room / Storage	MR	320.93	320.93	0.00	0.00	0.00	11/09/05 3:05 PM	11/23/05 12:00	230.60	0.00	0.00	0.00	230.60	189.07	0.00	0.00	0.00	189.07
23261	Mechanical Room / Storage	MR	320.92	320.92	0.00	0.00	0.00	11/09/05 3:06 PM	11/23/05 12:00	234.65	0.00	0.00	0.00	234.65	187.42	0.00	0.00	0.00	187.42
21313	Mechanical Room / Storage	MR	321.62	321.62	0.00	0.00	0.00	11/09/05 2:24 PM	11/23/05 12:00	321.62	0.00	0.00	0.00	321.62	213.45	0.00	0.00	0.00	213.45
21203	Mechanical Room / Storage	MR	321.67	321.67	0.00	0.00	0.00	11/09/05 2:21 PM	11/23/05 12:00	321.67	0.00	0.00	0.00	321.67	0.00	0.00	0.00	0.00	0.00
20653	Mechanical Room / Storage	MR	321.08	321.08	0.00	0.00	0.00	11/09/05 2:56 PM	11/23/05 12:00	188.75	0.00	0.00	0.00	188.75	53.27	0.00	0.00	0.00	53.27

Normalized Data Logger Detail Building type:Industrial Manufacturing. Building size:more than 1,000K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20643	Mechanical	MR	3100	122.84	0.00	0.00	0.00	122.84	119.01	0.00	0.00	0.00	119.01	3.12%
23631	Mechanical	MR	3150	122.57	0.00	0.00	0.00	122.57	105.88	0.00	0.00	0.00	105.88	13.62%
23680	Mechanical	MR	2400	168.00	0.00	0.00	0.00	168.00	41.87	0.00	0.00	0.00	41.87	75.08%
23582	Mechanical	MR	3150	110.16	0.00	0.00	0.00	110.16	108.22	0.00	0.00	0.00	108.22	1.76%
23543	Mechanical	MR	10000	110.62	0.00	0.00	0.00	110.62	37.52	0.00	0.00	0.00	37.52	66.08%
23303	Mechanical	MR	10000	167.98	0.00	0.00	0.00	167.98	67.43	0.00	0.00	0.00	67.43	59.86%
23638	Mechanical	MR	10000	168.00	0.00	0.00	0.00	168.00	119.71	0.00	0.00	0.00	119.71	28.74%
22699	Mechanical	MR	3150	120.71	0.00	0.00	0.00	120.71	98.97	0.00	0.00	0.00	98.97	18.01%
23261	Mechanical	MR	10800	122.84	0.00	0.00	0.00	122.84	98.11	0.00	0.00	0.00	98.11	20.13%
21313	Mechanical	MR	2400	168.00	0.00	0.00	0.00	168.00	111.50	0.00	0.00	0.00	111.50	33.63%
21203	Mechanical	MR	3200	168.00	0.00	0.00	0.00	168.00	0.00	0.00	0.00	0.00	0.00	00.00%
20653	Mechanical	MR	3000	98.76	0.00	0.00	0.00	98.76	27.87	0.00	0.00	0.00	27.87	71.78%

Building Summary Totals Building type:Industrial Manufacturing. Building size:more than 1,000K. Shifts:3

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Mechanical Room /	MR	12	64356	8841	0	0	0	8841	5020	0	0	0	5020
Building Totals			64356	8841			0	8841	5020			0	5020