


Area Type Averages

Building type:Industrial Manufacturing. Building size:100K to less than 250K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	3	464	41.38	0.00	0.00	0.00	41.38	24.08	0.00	0.00	0.00	24.08	41.81%
Meeting Rooms	M	2	3072	167.05	0.00	0.00	0.00	167.05	67.12	0.00	0.00	0.00	67.12	59.82%
Restroom	R	2	1152	167.99	0.00	0.00	0.00	167.99	74.31	0.00	0.00	0.00	74.31	55.77%
Hallway	H	1	1344	54.22	0.00	0.00	0.00	54.22	0.00	0.00	0.00	0.00	0.00	100.0%
Mechanical Room /	MR	1	3080	168.00	0.00	0.00	0.00	168.00	108.15	0.00	0.00	0.00	108.15	35.63%
Warehouse	W	3	3153	128.26	0.00	0.00	0.00	128.26	38.07	0.00	0.00	0.00	38.07	70.32%
Stock Room	ST	1	1920	72.06	0.00	0.00	0.00	72.06	10.34	0.00	0.00	0.00	10.34	85.65%
Open Office	OO	2	2592	168.00	0.00	0.00	0.00	168.00	65.22	0.00	0.00	0.00	65.22	61.18%
Manuf Floor	MF	2	6528	167.99	0.00	0.00	0.00	167.99	60.98	0.00	0.00	0.00	60.98	63.70%
Laboratory	LA	4	1332	165.01	0.00	0.00	0.00	165.01	58.73	0.00	0.00	0.00	58.73	64.41%
Building Average			49211	149.48			0.00	149.48	56.44			0.00	56.44	62.24%



Hours per Week for each Area Type

Data Logger Detail Building type:Industrial Manufacturing. Building size:100K to less than 250K. Shifts:2 Page 1 of 1

All Loggers Listed			Hours Installed							Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23768	Open Office	OO	589.23	589.23	0.00	0.00	0.00	10/28/05 10:47	11/22/05 12:00	589.23	0.00	0.00	0.00	589.23	156.50	0.00	0.00	0.00	156.50
22641	Stock Room	ST	588.72	588.72	0.00	0.00	0.00	10/28/05 11:18	11/22/05 12:00	252.53	0.00	0.00	0.00	252.53	36.23	0.00	0.00	0.00	36.23
21238	Warehouse	W	589.73	589.73	0.00	0.00	0.00	10/28/05 10:17	11/22/05 12:00	589.73	0.00	0.00	0.00	589.73	215.92	0.00	0.00	0.00	215.92
23502	Meeting Rooms	M	588.80	588.80	0.00	0.00	0.00	10/28/05 11:13	11/22/05 12:00	582.13	0.00	0.00	0.00	582.13	111.87	0.00	0.00	0.00	111.87
21612	Meeting Rooms	M	589.33	589.33	0.00	0.00	0.00	10/28/05 10:41	11/22/05 12:00	589.33	0.00	0.00	0.00	589.33	358.90	0.00	0.00	0.00	358.90
23516	Restroom	R	556.93	556.93	0.00	0.00	0.00	10/28/05 10:38	11/20/05 3:33 PM	556.92	0.00	0.00	0.00	556.92	170.13	0.00	0.00	0.00	170.13
23514	Restroom	R	588.65	588.65	0.00	0.00	0.00	10/28/05 11:22	11/22/05 12:00	588.55	0.00	0.00	0.00	588.55	340.92	0.00	0.00	0.00	340.92
22193	Laboratory	LA	589.57	589.57	0.00	0.00	0.00	10/28/05 10:27	11/22/05 12:00	589.57	0.00	0.00	0.00	589.57	187.27	0.00	0.00	0.00	187.27
23617	Manuf Floor	MF	588.02	588.02	0.00	0.00	0.00	10/28/05 12:00	11/22/05 12:00	588.02	0.00	0.00	0.00	588.02	241.12	0.00	0.00	0.00	241.12
23883	Warehouse	W	587.93	587.93	0.00	0.00	0.00	10/28/05 12:05	11/22/05 12:00	586.50	0.00	0.00	0.00	586.50	119.87	0.00	0.00	0.00	119.87
21276	Hallway	H	588.87	588.87	0.00	0.00	0.00	10/28/05 11:09	11/22/05 12:00	190.07	0.00	0.00	0.00	190.07	0.00	0.00	0.00	0.00	0.00
22735	Private Office	PO	588.90	588.90	0.00	0.00	0.00	10/28/05 11:07	11/22/05 12:00	139.52	0.00	0.00	0.00	139.52	72.60	0.00	0.00	0.00	72.60
20656	Private Office	PO	589.83	589.83	0.00	0.00	0.00	10/28/05 10:11	11/22/05 12:00	143.72	0.00	0.00	0.00	143.72	53.27	0.00	0.00	0.00	53.27
23750	Laboratory	LA	589.52	589.52	0.00	0.00	0.00	10/28/05 10:30	11/22/05 12:00	589.52	0.00	0.00	0.00	589.52	327.33	0.00	0.00	0.00	327.33
24030	Laboratory	LA	589.62	589.62	0.00	0.00	0.00	10/28/05 10:24	11/22/05 12:00	547.82	0.00	0.00	0.00	547.82	228.13	0.00	0.00	0.00	228.13
23630	Laboratory	LA	588.22	588.22	0.00	0.00	0.00	10/28/05 11:48	11/22/05 12:00	588.05	0.00	0.00	0.00	588.05	81.45	0.00	0.00	0.00	81.45
21456	Mechanical Room / Storage	MR	588.27	588.27	0.00	0.00	0.00	10/28/05 11:45	11/22/05 12:00	588.27	0.00	0.00	0.00	588.27	378.70	0.00	0.00	0.00	378.70
1	Open Office	OO	589.15	589.15	0.00	0.00	0.00	10/28/05 10:52	11/22/05 12:00	589.13	0.00	0.00	0.00	589.13	300.93	0.00	0.00	0.00	300.93
23336	Private Office	PO	588.40	588.40	0.00	0.00	0.00	10/28/05 11:37	11/22/05 12:00	152.03	0.00	0.00	0.00	152.03	127.35	0.00	0.00	0.00	127.35
2	Manuf Floor	MF	588.47	588.47	0.00	0.00	0.00	10/28/05 11:33	11/22/05 12:00	588.38	0.00	0.00	0.00	588.38	185.90	0.00	0.00	0.00	185.90
22440	Warehouse	W	588.53	588.53	0.00	0.00	0.00	10/28/05 11:29	11/22/05 12:00	172.33	0.00	0.00	0.00	172.33	64.60	0.00	0.00	0.00	64.60

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23768	Open Office	OO	2304	168.00	0.00	0.00	0.00	168.00	44.62	0.00	0.00	0.00	44.62	73.44%
22641	Stock Room	ST	1920	72.06	0.00	0.00	0.00	72.06	10.34	0.00	0.00	0.00	10.34	85.65%
21238	Warehouse	W	1080	168.00	0.00	0.00	0.00	168.00	61.51	0.00	0.00	0.00	61.51	63.39%
23502	Meeting Rooms	M	2688	166.10	0.00	0.00	0.00	166.10	31.92	0.00	0.00	0.00	31.92	80.78%
21612	Meeting Rooms	M	3456	168.00	0.00	0.00	0.00	168.00	102.31	0.00	0.00	0.00	102.31	39.10%
23516	Restroom	R	576	168.00	0.00	0.00	0.00	168.00	51.32	0.00	0.00	0.00	51.32	69.45%
23514	Restroom	R	1728	167.97	0.00	0.00	0.00	167.97	97.30	0.00	0.00	0.00	97.30	42.07%
22193	Laboratory	LA	720	168.00	0.00	0.00	0.00	168.00	53.36	0.00	0.00	0.00	53.36	68.24%
23617	Manuf Floor	MF	3456	168.00	0.00	0.00	0.00	168.00	68.89	0.00	0.00	0.00	68.89	58.99%
23883	Warehouse	W	1980	167.59	0.00	0.00	0.00	167.59	34.25	0.00	0.00	0.00	34.25	79.56%
21276	Hallway	H	1344	54.22	0.00	0.00	0.00	54.22	0.00	0.00	0.00	0.00	0.00	00.00%
22735	Private Office	PO	768	39.80	0.00	0.00	0.00	39.80	20.71	0.00	0.00	0.00	20.71	47.96%
20656	Private Office	PO	384	40.93	0.00	0.00	0.00	40.93	15.17	0.00	0.00	0.00	15.17	62.94%
23750	Laboratory	LA	1728	168.00	0.00	0.00	0.00	168.00	93.28	0.00	0.00	0.00	93.28	44.48%
24030	Laboratory	LA	1728	156.09	0.00	0.00	0.00	156.09	65.00	0.00	0.00	0.00	65.00	58.36%
23630	Laboratory	LA	1152	167.95	0.00	0.00	0.00	167.95	23.26	0.00	0.00	0.00	23.26	86.15%
21456	Mechanical	MR	3080	168.00	0.00	0.00	0.00	168.00	108.15	0.00	0.00	0.00	108.15	35.63%
1	Open Office	OO	2880	168.00	0.00	0.00	0.00	168.00	85.81	0.00	0.00	0.00	85.81	48.92%
23336	Private Office	PO	240	43.41	0.00	0.00	0.00	43.41	36.36	0.00	0.00	0.00	36.36	16.24%
2	Manuf Floor	MF	9600	167.98	0.00	0.00	0.00	167.98	53.07	0.00	0.00	0.00	53.07	68.41%
22440	Warehouse	W	6400	49.19	0.00	0.00	0.00	49.19	18.44	0.00	0.00	0.00	18.44	62.51%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	3	1392	58	0	0	0	58	34	0	0	0	34
Meeting Rooms	M	2	6144	1026	0	0	0	1026	412	0	0	0	412
Restroom	R	2	2304	387	0	0	0	387	171	0	0	0	171
Hallway	H	1	1344	73	0	0	0	73	0	0	0	0	0
Mechanical Room /	MR	1	3080	517	0	0	0	517	333	0	0	0	333
Warehouse	W	3	9459	1213	0	0	0	1213	360	0	0	0	360
Stock Room	ST	1	1920	138	0	0	0	138	20	0	0	0	20
Open Office	OO	2	5184	871	0	0	0	871	338	0	0	0	338
Manuf Floor	MF	2	13056	2193	0	0	0	2193	796	0	0	0	796
Laboratory	LA	4	5328	879	0	0	0	879	313	0	0	0	313
Building Totals			49211	7356	0			7356	2777	0			2777