


Area Type Averages

Building type:Industrial Manufacturing. Building size:100K to less than 250K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	6	303	45.34	0.00	0.00	45.34	33.92	0.00	0.00	0.00	33.92	25.19%	
Open Space	OS	1	1404	167.99	0.00	0.00	167.99	166.61	0.00	0.00	0.00	166.61	0.82%	
Storage	S	5	491	141.15	0.00	0.00	141.15	59.68	0.00	0.00	0.00	59.68	57.72%	
Hallway	H	3	1100	141.74	0.00	0.00	141.74	89.52	0.00	0.00	0.00	89.52	36.84%	
Copy Rm	C	1	176	11.62	0.00	0.00	11.62	9.53	0.00	0.00	0.00	9.53	17.99%	
Warehouse	W	5	726	166.81	0.00	0.00	166.81	42.80	0.00	0.00	0.00	42.80	74.34%	
Factory	FA	2	795	167.97	0.00	0.00	167.97	136.84	0.00	0.00	0.00	136.84	18.53%	
Cafeteria	CF	2	1012	93.39	0.00	0.00	93.39	67.78	0.00	0.00	0.00	67.78	27.42%	
Open Office	OO	9	1741	81.86	0.00	0.00	81.86	48.26	0.00	0.00	0.00	48.26	41.05%	
Conference	CN	1	528	38.65	0.00	0.00	38.65	23.92	0.00	0.00	0.00	23.92	38.11%	
Building Average			32594	107.36			107.36	61.92			0.00	61.92	42.32%	



Hours per Week for each Area Type

Data Logger Detail Building type:Industrial Manufacturing. Building size:100K to less than 250K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed						Lights On						Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
22906	Storage	S	335.03	335.03	0.00	0.00	0.00	10/10/05 12:57	10/24/05 11:58	335.02	0.00	0.00	0.00	335.02	89.43	0.00	0.00	0.00	89.43
22717	Warehouse	W	335.72	335.72	0.00	0.00	0.00	10/10/05 12:07	10/24/05 11:49	335.70	0.00	0.00	0.00	335.70	96.85	0.00	0.00	0.00	96.85
22166	Warehouse	W	335.68	335.68	0.00	0.00	0.00	10/10/05 12:09	10/24/05 11:49	335.67	0.00	0.00	0.00	335.67	71.23	0.00	0.00	0.00	71.23
22250	Open Office	OO	347.55	347.55	0.00	0.00	0.00	10/10/05 12:28	10/25/05 12:00	115.00	0.00	0.00	0.00	115.00	104.60	0.00	0.00	0.00	104.60
22061	Factory	FA	334.88	334.88	0.00	0.00	0.00	10/10/05 12:43	10/24/05 11:35	334.77	0.00	0.00	0.00	334.77	274.87	0.00	0.00	0.00	274.87
24683	Open Office	OO	0.02	0.02	0.00	0.00	0.00	10/10/05 12:28	10/10/05 12:28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22073	Open Office	OO	334.95	334.95	0.00	0.00	0.00	10/10/05 12:35	10/24/05 11:31	229.57	0.00	0.00	0.00	229.57	200.30	0.00	0.00	0.00	200.30
22371	Open Office	OO	335.07	335.07	0.00	0.00	0.00	10/10/05 12:25	10/24/05 11:28	335.05	0.00	0.00	0.00	335.05	193.15	0.00	0.00	0.00	193.15
21812	Storage	S	334.65	334.65	0.00	0.00	0.00	10/10/05 12:49	10/24/05 11:27	76.63	0.00	0.00	0.00	76.63	50.40	0.00	0.00	0.00	50.40
20709	Factory	FA	334.88	334.88	0.00	0.00	0.00	10/10/05 12:44	10/24/05 11:36	334.87	0.00	0.00	0.00	334.87	270.67	0.00	0.00	0.00	270.67
22160	Open Office	OO	334.95	334.95	0.00	0.00	0.00	10/10/05 12:37	10/24/05 11:33	248.37	0.00	0.00	0.00	248.37	92.00	0.00	0.00	0.00	92.00
23452	Private Office	PO	335.03	335.03	0.00	0.00	0.00	10/10/05 12:29	10/24/05 11:30	205.97	0.00	0.00	0.00	205.97	140.20	0.00	0.00	0.00	140.20
21091	Warehouse	W	334.92	334.92	0.00	0.00	0.00	10/10/05 12:40	10/24/05 11:34	334.90	0.00	0.00	0.00	334.90	105.80	0.00	0.00	0.00	105.80
22275	Cafeteria	CF	336.15	336.15	0.00	0.00	0.00	10/10/05 11:38	10/24/05 11:46	99.37	0.00	0.00	0.00	99.37	75.47	0.00	0.00	0.00	75.47
22677	Cafeteria	CF	336.52	336.52	0.00	0.00	0.00	10/10/05 11:35	10/24/05 12:05	274.67	0.00	0.00	0.00	274.67	195.97	0.00	0.00	0.00	195.97
21771	Conference	CN	336.02	336.02	0.00	0.00	0.00	10/10/05 11:43	10/24/05 11:43	77.30	0.00	0.00	0.00	77.30	47.83	0.00	0.00	0.00	47.83
21850	Copy Rm	C	335.68	335.68	0.00	0.00	0.00	10/10/05 12:04	10/24/05 11:44	23.22	0.00	0.00	0.00	23.22	19.05	0.00	0.00	0.00	19.05
22832	Open Office	OO	335.93	335.93	0.00	0.00	0.00	10/10/05 11:26	10/24/05 11:21	110.52	0.00	0.00	0.00	110.52	0.50	0.00	0.00	0.00	0.50
21556	Hallway	H	334.92	334.92	0.00	0.00	0.00	10/10/05 1:08 PM	10/24/05 12:02	334.90	0.00	0.00	0.00	334.90	257.10	0.00	0.00	0.00	257.10
22343	Open Space	OS	335.62	335.62	0.00	0.00	0.00	10/10/05 12:15	10/24/05 11:51	335.60	0.00	0.00	0.00	335.60	332.83	0.00	0.00	0.00	332.83
23292	Private Office	PO	336.57	336.57	0.00	0.00	0.00	10/10/05 11:29	10/24/05 12:02	96.78	0.00	0.00	0.00	96.78	88.72	0.00	0.00	0.00	88.72
21879	Open Office	OO	335.77	335.77	0.00	0.00	0.00	10/10/05 12:05	10/24/05 11:50	77.27	0.00	0.00	0.00	77.27	72.03	0.00	0.00	0.00	72.03
21944	Storage	S	335.10	335.10	0.00	0.00	0.00	10/10/05 12:55	10/24/05 12:00	334.28	0.00	0.00	0.00	334.28	264.95	0.00	0.00	0.00	264.95
21527	Hallway	H	335.70	335.70	0.00	0.00	0.00	10/10/05 11:58	10/24/05 11:39	335.58	0.00	0.00	0.00	335.58	170.80	0.00	0.00	0.00	170.80
23039	Open Office	OO	335.62	335.62	0.00	0.00	0.00	10/10/05 12:02	10/24/05 11:38	106.78	0.00	0.00	0.00	106.78	102.05	0.00	0.00	0.00	102.05
24176	Private Office	PO	336.57	336.57	0.00	0.00	0.00	10/10/05 11:31	10/24/05 12:04	78.93	0.00	0.00	0.00	78.93	63.50	0.00	0.00	0.00	63.50
22198	Private Office	PO	336.53	336.53	0.00	0.00	0.00	10/10/05 11:32	10/24/05 12:03	96.25	0.00	0.00	0.00	96.25	55.12	0.00	0.00	0.00	55.12
20673	Open Office	OO	336.07	336.07	0.00	0.00	0.00	10/10/05 11:40	10/24/05 11:43	252.18	0.00	0.00	0.00	252.18	106.05	0.00	0.00	0.00	106.05
24641	Warehouse	W	335.65	335.65	0.00	0.00	0.00	10/10/05 12:12	10/24/05 11:50	335.57	0.00	0.00	0.00	335.57	95.63	0.00	0.00	0.00	95.63
23772	Storage	S	335.05	335.05	0.00	0.00	0.00	10/10/05 12:59	10/24/05 12:01	326.47	0.00	0.00	0.00	326.47	139.03	0.00	0.00	0.00	139.03
24648	Storage	S	334.98	334.98	0.00	0.00	0.00	10/10/05 1:00 PM	10/24/05 11:58	334.97	0.00	0.00	0.00	334.97	51.30	0.00	0.00	0.00	51.30
20947	Hallway	H	335.73	335.73	0.00	0.00	0.00	10/10/05 11:56	10/24/05 11:39	178.42	0.00	0.00	0.00	178.42	108.15	0.00	0.00	0.00	108.15
21301	Private Office	PO	336.12	336.12	0.00	0.00	0.00	10/10/05 11:39	10/24/05 11:45	41.33	0.00	0.00	0.00	41.33	35.20	0.00	0.00	0.00	35.20
22271	Private Office	PO	335.88	335.88	0.00	0.00	0.00	10/10/05 11:49	10/24/05 11:41	24.67	0.00	0.00	0.00	24.67	24.30	0.00	0.00	0.00	24.30
21994	Warehouse	W	347.73	347.73	0.00	0.00	0.00	10/10/05 12:17	10/25/05 12:00	335.58	0.00	0.00	0.00	335.58	59.87	0.00	0.00	0.00	59.87

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
22906	Storage	S	660	167.99	0.00	0.00	0.00	167.99	44.85	0.00	0.00	0.00	44.85	73.30%
22717	Warehouse	W	702	167.99	0.00	0.00	0.00	167.99	48.47	0.00	0.00	0.00	48.47	71.15%
22166	Warehouse	W	660	167.99	0.00	0.00	0.00	167.99	35.65	0.00	0.00	0.00	35.65	78.78%
22250	Open Office	OO	1584	55.59	0.00	0.00	0.00	55.59	50.56	0.00	0.00	0.00	50.56	9.05%
22061	Factory	FA	600	167.94	0.00	0.00	0.00	167.94	137.89	0.00	0.00	0.00	137.89	17.89%
24683	Open Office	OO	528	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00%
22073	Open Office	OO	1320	115.14	0.00	0.00	0.00	115.14	100.46	0.00	0.00	0.00	100.46	12.75%
22371	Open Office	OO	1650	167.99	0.00	0.00	0.00	167.99	96.84	0.00	0.00	0.00	96.84	42.35%
21812	Storage	S	234	38.47	0.00	0.00	0.00	38.47	25.30	0.00	0.00	0.00	25.30	34.23%
20709	Factory	FA	990	167.99	0.00	0.00	0.00	167.99	135.78	0.00	0.00	0.00	135.78	19.17%
22160	Open Office	OO	660	124.57	0.00	0.00	0.00	124.57	46.14	0.00	0.00	0.00	46.14	62.96%
23452	Private Office	PO	528	103.28	0.00	0.00	0.00	103.28	70.30	0.00	0.00	0.00	70.30	31.93%
21091	Warehouse	W	1200	167.99	0.00	0.00	0.00	167.99	53.07	0.00	0.00	0.00	53.07	68.41%
22275	Cafeteria	CF	264	49.66	0.00	0.00	0.00	49.66	37.72	0.00	0.00	0.00	37.72	24.04%
22677	Cafeteria	CF	1760	137.12	0.00	0.00	0.00	137.12	97.83	0.00	0.00	0.00	97.83	28.65%
21771	Conference	CN	528	38.65	0.00	0.00	0.00	38.65	23.92	0.00	0.00	0.00	23.92	38.11%
21850	Copy Rm	C	176	11.62	0.00	0.00	0.00	11.62	9.53	0.00	0.00	0.00	9.53	17.99%
22832	Open Office	OO	2200	55.27	0.00	0.00	0.00	55.27	0.25	0.00	0.00	0.00	0.25	99.55%
21556	Hallway	H	660	167.99	0.00	0.00	0.00	167.99	128.97	0.00	0.00	0.00	128.97	23.23%
22343	Open Space	OS	1404	167.99	0.00	0.00	0.00	167.99	166.61	0.00	0.00	0.00	166.61	0.82%
23292	Private Office	PO	195	48.31	0.00	0.00	0.00	48.31	44.28	0.00	0.00	0.00	44.28	8.34%
21879	Open Office	OO	1430	38.66	0.00	0.00	0.00	38.66	36.04	0.00	0.00	0.00	36.04	6.78%
21944	Storage	S	360	167.59	0.00	0.00	0.00	167.59	132.83	0.00	0.00	0.00	132.83	20.74%
21527	Hallway	H	2200	167.94	0.00	0.00	0.00	167.94	85.48	0.00	0.00	0.00	85.48	49.10%
23039	Open Office	OO	2780	53.45	0.00	0.00	0.00	53.45	51.08	0.00	0.00	0.00	51.08	4.43%
24176	Private Office	PO	260	39.40	0.00	0.00	0.00	39.40	31.70	0.00	0.00	0.00	31.70	19.54%
22198	Private Office	PO	220	48.05	0.00	0.00	0.00	48.05	27.51	0.00	0.00	0.00	27.51	42.75%
20673	Open Office	OO	3520	126.07	0.00	0.00	0.00	126.07	53.01	0.00	0.00	0.00	53.01	57.95%
24641	Warehouse	W	468	167.96	0.00	0.00	0.00	167.96	47.87	0.00	0.00	0.00	47.87	71.50%
23772	Storage	S	420	163.70	0.00	0.00	0.00	163.70	69.71	0.00	0.00	0.00	69.71	57.42%
24648	Storage	S	780	167.99	0.00	0.00	0.00	167.99	25.73	0.00	0.00	0.00	25.73	84.68%
20947	Hallway	H	440	89.28	0.00	0.00	0.00	89.28	54.12	0.00	0.00	0.00	54.12	39.38%
21301	Private Office	PO	264	20.66	0.00	0.00	0.00	20.66	17.59	0.00	0.00	0.00	17.59	14.86%
22271	Private Office	PO	352	12.34	0.00	0.00	0.00	12.34	12.15	0.00	0.00	0.00	12.15	1.54%
21994	Warehouse	W	600	162.13	0.00	0.00	0.00	162.13	28.92	0.00	0.00	0.00	28.92	82.16%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	6	1818	82	0	0	0	82	62	0	0	0	62
Open Space	OS	1	1404	236	0	0	0	236	234	0	0	0	234
Storage	S	5	2455	347	0	0	0	347	147	0	0	0	147
Hallway	H	3	3300	468	0	0	0	468	295	0	0	0	295
Copy Rm	C	1	176	2	0	0	0	2	2	0	0	0	2
Warehouse	W	5	3630	606	0	0	0	606	155	0	0	0	155
Factory	FA	2	1590	267	0	0	0	267	218	0	0	0	218
Cafeteria	CF	2	2024	189	0	0	0	189	137	0	0	0	137
Open Office	OO	9	15669	1283	0	0	0	1283	756	0	0	0	756
Conference	CN	1	528	20	0	0	0	20	13	0	0	0	13
Building Totals			32594	3499			0	3499	2018			0	2018