


Area Type Averages

Building type:Office. Building size:less than 10K. Shifts:1

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	2	292	36.04	0.00	0.00	0.00	36.04	13.37	0.00	0.00	0.00	13.37	62.90%
Kitchen	K	1	220	7.71	0.00	0.00	0.00	7.71	6.03	0.00	0.00	0.00	6.03	21.79%
Office	O	12	272	25.52	0.00	0.00	0.00	25.52	20.01	0.00	0.00	0.00	20.01	21.59%
Building Average			4068	26.07			0.00	26.07	18.30			0.00	18.30	29.80%



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:less than 10K. Shifts:1

All Loggers Listed			Hours Installed					Installed		Removed		Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total		
20121	Office	O	334.18	334.18	0.00	0.00	0.00	10/11/05 8:50 PM	10/25/05 7:00 PM	91.50	0.00	0.00	0.00	91.50	75.30	0.00	0.00	0.00	75.30		
20395	Office	O	334.13	334.13	0.00	0.00	0.00	10/11/05 8:53 PM	10/25/05 7:00 PM	34.72	0.00	0.00	0.00	34.72	29.78	0.00	0.00	0.00	29.78		
20225	Office	O	334.35	334.35	0.00	0.00	0.00	10/11/05 8:40 PM	10/25/05 7:00 PM	74.20	0.00	0.00	0.00	74.20	47.83	0.00	0.00	0.00	47.83		
20389	Office	O	334.12	334.12	0.00	0.00	0.00	10/11/05 8:54 PM	10/25/05 7:00 PM	21.23	0.00	0.00	0.00	21.23	3.40	0.00	0.00	0.00	3.40		
20404	Office	O	321.87	321.87	0.00	0.00	0.00	10/12/05 9:09 AM	10/25/05 7:00 PM	1.13	0.00	0.00	0.00	1.13	0.93	0.00	0.00	0.00	0.93		
20128	Kitchen	K	323.17	323.17	0.00	0.00	0.00	10/12/05 7:51 AM	10/25/05 7:00 PM	14.83	0.00	0.00	0.00	14.83	11.60	0.00	0.00	0.00	11.60		
20118	Office	O	322.98	322.98	0.00	0.00	0.00	10/12/05 8:02 AM	10/25/05 7:00 PM	87.53	0.00	0.00	0.00	87.53	78.80	0.00	0.00	0.00	78.80		
20226	Restroom	R	334.03	334.03	0.00	0.00	0.00	10/11/05 8:59 PM	10/25/05 7:00 PM	96.40	0.00	0.00	0.00	96.40	37.40	0.00	0.00	0.00	37.40		
20177	Office	O	322.83	322.83	0.00	0.00	0.00	10/12/05 8:11 AM	10/25/05 7:00 PM	5.90	0.00	0.00	0.00	5.90	4.93	0.00	0.00	0.00	4.93		
20325	Office	O	342.93	342.93	0.00	0.00	0.00	10/12/05 10:25	10/26/05 5:20 PM	27.53	0.00	0.00	0.00	27.53	15.70	0.00	0.00	0.00	15.70		
20140	Office	O	320.40	320.40	0.00	0.00	0.00	10/12/05 10:37	10/25/05 7:00 PM	9.50	0.00	0.00	0.00	9.50	8.47	0.00	0.00	0.00	8.47		
20154	Office	O	334.65	334.65	0.00	0.00	0.00	10/11/05 8:22 PM	10/25/05 7:00 PM	124.12	0.00	0.00	0.00	124.12	111.58	0.00	0.00	0.00	111.58		
20409	Office	O	334.40	334.40	0.00	0.00	0.00	10/11/05 8:37 PM	10/25/05 7:00 PM	81.12	0.00	0.00	0.00	81.12	60.68	0.00	0.00	0.00	60.68		
20440	Office	O	334.42	334.42	0.00	0.00	0.00	10/11/05 8:36 PM	10/25/05 7:00 PM	48.07	0.00	0.00	0.00	48.07	37.60	0.00	0.00	0.00	37.60		
20252	Restroom	R	321.38	321.38	0.00	0.00	0.00	10/12/05 9:38 AM	10/25/05 7:00 PM	45.13	0.00	0.00	0.00	45.13	15.17	0.00	0.00	0.00	15.17		

Normalized Data Logger Detail Building type:Office. Building size:less than 10K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20121	Office	O	168	46.00	0.00	0.00	0.00	46.00	37.85	0.00	0.00	0.00	37.85	17.72%
20395	Office	O	168	17.46	0.00	0.00	0.00	17.46	14.97	0.00	0.00	0.00	14.97	14.26%
20225	Office	O	224	37.28	0.00	0.00	0.00	37.28	24.03	0.00	0.00	0.00	24.03	35.54%
20389	Office	O	96	10.68	0.00	0.00	0.00	10.68	1.71	0.00	0.00	0.00	1.71	83.99%
20404	Office	O	336	0.59	0.00	0.00	0.00	0.59	0.49	0.00	0.00	0.00	0.49	16.95%
20128	Kitchen	K	220	7.71	0.00	0.00	0.00	7.71	6.03	0.00	0.00	0.00	6.03	21.79%
20118	Office	O	168	45.53	0.00	0.00	0.00	45.53	40.99	0.00	0.00	0.00	40.99	9.97%
20226	Restroom	R	324	48.48	0.00	0.00	0.00	48.48	18.81	0.00	0.00	0.00	18.81	61.20%
20177	Office	O	693	3.07	0.00	0.00	0.00	3.07	2.57	0.00	0.00	0.00	2.57	16.29%
20325	Office	O	168	13.49	0.00	0.00	0.00	13.49	7.69	0.00	0.00	0.00	7.69	42.99%
20140	Office	O	96	4.98	0.00	0.00	0.00	4.98	4.44	0.00	0.00	0.00	4.44	10.84%
20154	Office	O	640	62.31	0.00	0.00	0.00	62.31	56.02	0.00	0.00	0.00	56.02	10.09%
20409	Office	O	336	40.75	0.00	0.00	0.00	40.75	30.49	0.00	0.00	0.00	30.49	25.18%
20440	Office	O	168	24.15	0.00	0.00	0.00	24.15	18.89	0.00	0.00	0.00	18.89	21.78%
20252	Restroom	R	260	23.59	0.00	0.00	0.00	23.59	7.93	0.00	0.00	0.00	7.93	66.38%

Building Summary Totals Building type:Office. Building size:less than 10K. Shifts:1

Building Summary Totals				Lights On KwHR					Occupied KwHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Restroom	R	2	584	21	0	0	21	8	0	0	0	8	
Kitchen	K	1	220	2	0	0	2	1	0	0	0	1	
Office	O	12	3264	83	0	0	83	65	0	0	0	65	
Building Totals			4068	106			106	74				74	