


# Area Type Averages

Building type:Office. Building size:100K to less than 250K. Shifts:1

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Kitchen	K	1	352	54.07	0.00	0.00	0.00	54.07	26.46	0.00	0.00	0.00	26.46	51.06%
Office	O	8	242	33.83	0.00	0.00	0.00	33.83	26.61	0.00	0.00	0.00	26.61	21.34%
Building Average			2288	36.94			0.00	36.94	26.59			0.00	26.59	28.02%



**Hours per Week for each Area Type**

## Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23857	Office	O	445.23	445.23	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:13	118.78	0.00	0.00	0.00	118.78	111.25	0.00	0.00	0.00	111.25
23981	Office	O	445.37	445.37	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:21	164.03	0.00	0.00	0.00	164.03	152.00	0.00	0.00	0.00	152.00
23870	Office	O	445.35	445.35	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:20	71.32	0.00	0.00	0.00	71.32	53.88	0.00	0.00	0.00	53.88
23399	Kitchen	K	445.27	445.27	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:15	143.32	0.00	0.00	0.00	143.32	70.13	0.00	0.00	0.00	70.13
23184	Office	O	445.37	445.37	0.00	0.00	0.00	10/27/05 1:00 AM	11/14/05 2:21 PM	60.28	0.00	0.00	0.00	60.28	31.47	0.00	0.00	0.00	31.47
24370	Office	O	445.33	445.33	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:19	57.23	0.00	0.00	0.00	57.23	40.40	0.00	0.00	0.00	40.40
20895	Office	O	456.02	456.02	0.00	0.00	0.00	10/26/05 11:00	11/14/05 11:00	95.17	0.00	0.00	0.00	95.17	79.45	0.00	0.00	0.00	79.45
24016	Office	O	445.30	445.30	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:17	107.72	0.00	0.00	0.00	107.72	93.45	0.00	0.00	0.00	93.45
23092	Office	O	445.22	445.22	0.00	0.00	0.00	10/26/05 11:00	11/14/05 12:12	44.97	0.00	0.00	0.00	44.97	4.20	0.00	0.00	0.00	4.20

## Normalized Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23857	Office	O	176	44.82	0.00	0.00	0.00	44.82	41.98	0.00	0.00	0.00	41.98	6.34%
23981	Office	O	176	61.88	0.00	0.00	0.00	61.88	57.34	0.00	0.00	0.00	57.34	7.34%
23870	Office	O	176	26.90	0.00	0.00	0.00	26.90	20.33	0.00	0.00	0.00	20.33	24.42%
23399	Kitchen	K	352	54.07	0.00	0.00	0.00	54.07	26.46	0.00	0.00	0.00	26.46	51.06%
23184	Office	O	700	22.74	0.00	0.00	0.00	22.74	11.87	0.00	0.00	0.00	11.87	47.80%
24370	Office	O	176	21.59	0.00	0.00	0.00	21.59	15.24	0.00	0.00	0.00	15.24	29.41%
20895	Office	O	176	35.06	0.00	0.00	0.00	35.06	29.27	0.00	0.00	0.00	29.27	16.51%
24016	Office	O	176	40.64	0.00	0.00	0.00	40.64	35.26	0.00	0.00	0.00	35.26	13.24%
23092	Office	O	176	16.97	0.00	0.00	0.00	16.97	1.58	0.00	0.00	0.00	1.58	90.69%

## Building Summary Totals Building type:Office. Building size:100K to less than 250K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Kitchen	K	1	352	19	0	0	19	9	0	0	0	9	
Office	O	8	1936	65	0	0	65	52	0	0	0	52	
Building Totals			2288	85		0	85	61			0	61	