


# Area Type Averages

Building type:Office. Building size:100K to less than 250K. Shifts:1

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	1	480	167.37	0.00	0.00	0.00	167.37	56.18	0.00	0.00	0.00	56.18	66.43%
Copy Rm	C	2	840	143.87	0.00	0.00	0.00	143.87	49.90	0.00	0.00	0.00	49.90	65.32%
Garage	GR	1	1500	167.98	0.00	0.00	0.00	167.98	56.21	0.00	0.00	0.00	56.21	66.54%
Cafeteria	CF	3	907	167.98	0.00	0.00	0.00	167.98	47.58	0.00	0.00	0.00	47.58	71.68%
Office	O	1	160	47.49	0.00	0.00	0.00	47.49	41.19	0.00	0.00	0.00	41.19	13.27%
Computer Room	CP	1	380	119.72	0.00	0.00	0.00	119.72	29.11	0.00	0.00	0.00	29.11	75.68%
Conference	CN	10	1041	117.95	0.00	0.00	0.00	117.95	27.29	0.00	0.00	0.00	27.29	76.86%
Lobby	LB	1	160	167.99	0.00	0.00	0.00	167.99	29.94	0.00	0.00	0.00	29.94	82.18%
Food Services	FS	1	640	119.73	0.00	0.00	0.00	119.73	61.80	0.00	0.00	0.00	61.80	48.38%
Building Average			18131	133.23			0.00	133.23	36.99			0.00	36.99	72.24%



**Hours per Week for each Area Type**

Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

All Loggers Listed			Hours Installed							Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20747	Conference	CN	335.95	335.95	0.00	0.00	0.00	9/09/05 2:16 PM	9/23/05 2:12 PM	63.80	0.00	0.00	0.00	63.80	48.67	0.00	0.00	0.00	48.67
22202	Conference	CN	335.92	335.92	0.00	0.00	0.00	9/09/05 2:20 PM	9/23/05 2:14 PM	59.27	0.00	0.00	0.00	59.27	49.13	0.00	0.00	0.00	49.13
21045	Computer Room	CP	335.73	335.73	0.00	0.00	0.00	9/09/05 2:46 PM	9/23/05 2:29 PM	239.25	0.00	0.00	0.00	239.25	58.17	0.00	0.00	0.00	58.17
20633	Conference	CN	335.87	335.87	0.00	0.00	0.00	9/09/05 2:30 PM	9/23/05 2:21 PM	239.38	0.00	0.00	0.00	239.38	58.95	0.00	0.00	0.00	58.95
22173	Food Services	FS	335.82	335.82	0.00	0.00	0.00	9/09/05 2:32 PM	9/23/05 2:20 PM	239.33	0.00	0.00	0.00	239.33	123.53	0.00	0.00	0.00	123.53
20896	Lobby	LB	335.42	335.42	0.00	0.00	0.00	9/09/05 2:53 PM	9/23/05 2:17 PM	335.40	0.00	0.00	0.00	335.40	59.77	0.00	0.00	0.00	59.77
21733	Conference	CN	335.32	335.32	0.00	0.00	0.00	9/09/05 2:56 PM	9/23/05 2:14 PM	335.30	0.00	0.00	0.00	335.30	41.60	0.00	0.00	0.00	41.60
20993	Conference	CN	330.85	330.85	0.00	0.00	0.00	9/09/05 2:51 PM	9/23/05 9:41 AM	75.83	0.00	0.00	0.00	75.83	49.67	0.00	0.00	0.00	49.67
22334	Copy Rm	C	335.35	335.35	0.00	0.00	0.00	9/09/05 2:55 PM	9/23/05 2:15 PM	335.33	0.00	0.00	0.00	335.33	86.15	0.00	0.00	0.00	86.15
21895	Garage	GR	335.52	335.52	0.00	0.00	0.00	9/09/05 3:03 PM	9/23/05 2:33 PM	335.47	0.00	0.00	0.00	335.47	112.25	0.00	0.00	0.00	112.25
22907	Cafeteria	CF	335.95	335.95	0.00	0.00	0.00	9/09/05 2:26 PM	9/23/05 2:22 PM	335.87	0.00	0.00	0.00	335.87	115.98	0.00	0.00	0.00	115.98
22951	Conference	CN	335.85	335.85	0.00	0.00	0.00	9/09/05 2:36 PM	9/23/05 2:26 PM	335.83	0.00	0.00	0.00	335.83	59.23	0.00	0.00	0.00	59.23
21401	Conference	CN	335.73	335.73	0.00	0.00	0.00	9/09/05 2:44 PM	9/23/05 2:27 PM	335.72	0.00	0.00	0.00	335.72	60.00	0.00	0.00	0.00	60.00
22660	Conference	CN	335.78	335.78	0.00	0.00	0.00	9/09/05 2:41 PM	9/23/05 2:27 PM	335.77	0.00	0.00	0.00	335.77	55.73	0.00	0.00	0.00	55.73
22903	Conference	CN	335.75	335.75	0.00	0.00	0.00	9/09/05 2:43 PM	9/23/05 2:27 PM	335.73	0.00	0.00	0.00	335.73	50.57	0.00	0.00	0.00	50.57
21388	Conference	CN	335.82	335.82	0.00	0.00	0.00	9/09/05 2:37 PM	9/23/05 2:25 PM	239.33	0.00	0.00	0.00	239.33	71.10	0.00	0.00	0.00	71.10
21247	Cafeteria	CF	336.00	336.00	0.00	0.00	0.00	9/09/05 2:24 PM	9/23/05 2:23 PM	335.98	0.00	0.00	0.00	335.98	118.47	0.00	0.00	0.00	118.47
20855	Cafeteria	CF	335.93	335.93	0.00	0.00	0.00	9/09/05 2:28 PM	9/23/05 2:23 PM	335.92	0.00	0.00	0.00	335.92	51.00	0.00	0.00	0.00	51.00
23014	Copy Rm	C	335.85	335.85	0.00	0.00	0.00	9/09/05 2:39 PM	9/23/05 2:29 PM	239.37	0.00	0.00	0.00	239.37	113.22	0.00	0.00	0.00	113.22
21782	Restroom	R	335.77	335.77	0.00	0.00	0.00	9/09/05 2:34 PM	9/23/05 2:19 PM	334.52	0.00	0.00	0.00	334.52	112.28	0.00	0.00	0.00	112.28
20826	Office	O	335.03	335.03	0.00	0.00	0.00	9/09/05 3:10 PM	9/23/05 2:11 PM	94.72	0.00	0.00	0.00	94.72	82.15	0.00	0.00	0.00	82.15

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20747	Conference	CN	325	31.90	0.00	0.00	0.00	31.90	24.34	0.00	0.00	0.00	24.34	23.70%
22202	Conference	CN	325	29.64	0.00	0.00	0.00	29.64	24.57	0.00	0.00	0.00	24.57	17.11%
21045	Computer	CP	380	119.72	0.00	0.00	0.00	119.72	29.11	0.00	0.00	0.00	29.11	75.68%
20633	Conference	CN	1280	119.74	0.00	0.00	0.00	119.74	29.49	0.00	0.00	0.00	29.49	75.37%
22173	Food Services	FS	640	119.73	0.00	0.00	0.00	119.73	61.80	0.00	0.00	0.00	61.80	48.38%
20896	Lobby	LB	160	167.99	0.00	0.00	0.00	167.99	29.94	0.00	0.00	0.00	29.94	82.18%
21733	Conference	CN	2720	167.99	0.00	0.00	0.00	167.99	20.84	0.00	0.00	0.00	20.84	87.59%
20993	Conference	CN	2720	38.51	0.00	0.00	0.00	38.51	25.22	0.00	0.00	0.00	25.22	34.51%
22334	Copy Rm	C	160	167.99	0.00	0.00	0.00	167.99	43.16	0.00	0.00	0.00	43.16	74.31%
21895	Garage	GR	1500	167.98	0.00	0.00	0.00	167.98	56.21	0.00	0.00	0.00	56.21	66.54%
22907	Cafeteria	CF	1280	167.96	0.00	0.00	0.00	167.96	58.00	0.00	0.00	0.00	58.00	65.47%
22951	Conference	CN	320	167.99	0.00	0.00	0.00	167.99	29.63	0.00	0.00	0.00	29.63	82.36%
21401	Conference	CN	640	167.99	0.00	0.00	0.00	167.99	30.02	0.00	0.00	0.00	30.02	82.13%
22660	Conference	CN	320	167.99	0.00	0.00	0.00	167.99	27.88	0.00	0.00	0.00	27.88	83.40%
22903	Conference	CN	320	167.99	0.00	0.00	0.00	167.99	25.30	0.00	0.00	0.00	25.30	84.94%
21388	Conference	CN	1440	119.73	0.00	0.00	0.00	119.73	35.57	0.00	0.00	0.00	35.57	70.29%
21247	Cafeteria	CF	1280	167.99	0.00	0.00	0.00	167.99	59.23	0.00	0.00	0.00	59.23	64.74%
20855	Cafeteria	CF	160	167.99	0.00	0.00	0.00	167.99	25.51	0.00	0.00	0.00	25.51	84.81%
23014	Copy Rm	C	1520	119.74	0.00	0.00	0.00	119.74	56.63	0.00	0.00	0.00	56.63	52.71%
21782	Restroom	R	480	167.37	0.00	0.00	0.00	167.37	56.18	0.00	0.00	0.00	56.18	66.43%
20826	Office	O	160	47.49	0.00	0.00	0.00	47.49	41.19	0.00	0.00	0.00	41.19	13.27%

Building Summary Totals Building type:Office. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	1	480	80	0	0	0	80	27	0	0	0	27
Copy Rm	C	2	1680	242	0	0	0	242	84	0	0	0	84
Garage	GR	1	1500	252	0	0	0	252	84	0	0	0	84
Cafeteria	CF	3	2721	457	0	0	0	457	129	0	0	0	129
Office	O	1	160	8	0	0	0	8	7	0	0	0	7
Computer Room	CP	1	380	45	0	0	0	45	11	0	0	0	11
Conference	CN	10	10410	1228	0	0	0	1228	284	0	0	0	284
Lobby	LB	1	160	27	0	0	0	27	5	0	0	0	5
Food Services	FS	1	640	77	0	0	0	77	40	0	0	0	40
Building Totals			18131	2416			0	2416	671			0	671