


Area Type Averages

Building type:Office. Building size:10K to less than 25K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	3	293	76.21	0.00	0.00	76.21	43.70	0.00	0.00	0.00	43.70	42.66%	
Restroom	R	2	240	166.84	0.00	0.00	166.84	62.91	0.00	0.00	0.00	62.91	62.29%	
Kitchen	K	1	80	168.00	0.00	0.00	168.00	93.10	0.00	0.00	0.00	93.10	44.58%	
Open Office	OO	3	453	87.51	0.00	0.00	87.51	56.04	0.00	0.00	0.00	56.04	35.96%	
MultiPurpose Rm	MP	7	503	151.65	0.00	0.00	151.65	66.38	0.00	0.00	0.00	66.38	56.23%	
Building Average			6319	128.72		0.00	128.72	61.08		0.00	0.00	61.08	52.55%	



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:10K to less than 25K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23139	Open Office	OO	345.07	345.07	0.00	0.00	0.00	6/14/05 2:57 PM	6/29/05 12:00 AM	109.30	0.00	0.00	0.00	109.30	89.53	0.00	0.00	0.00	89.53
21264	MultiPurpose Rm	MP	344.75	344.75	0.00	0.00	0.00	6/14/05 3:16 PM	6/29/05 12:00 AM	314.95	0.00	0.00	0.00	314.95	123.43	0.00	0.00	0.00	123.43
23480	Private Office	PO	336.88	336.88	0.00	0.00	0.00	6/14/05 11:08 PM	6/29/05 12:00 AM	165.60	0.00	0.00	0.00	165.60	112.60	0.00	0.00	0.00	112.60
21335	MultiPurpose Rm	MP	344.92	344.92	0.00	0.00	0.00	6/14/05 3:06 PM	6/29/05 12:00 AM	257.42	0.00	0.00	0.00	257.42	71.43	0.00	0.00	0.00	71.43
21515	Kitchen	K	344.83	344.83	0.00	0.00	0.00	6/14/05 3:11 PM	6/29/05 12:00 AM	344.83	0.00	0.00	0.00	344.83	191.10	0.00	0.00	0.00	191.10
23449	Restroom	R	344.80	344.80	0.00	0.00	0.00	6/14/05 3:13 PM	6/29/05 12:00 AM	340.30	0.00	0.00	0.00	340.30	92.13	0.00	0.00	0.00	92.13
20763	MultiPurpose Rm	MP	344.60	344.60	0.00	0.00	0.00	6/14/05 3:25 PM	6/29/05 12:00 AM	344.60	0.00	0.00	0.00	344.60	213.15	0.00	0.00	0.00	213.15
21440	Restroom	R	344.78	344.78	0.00	0.00	0.00	6/14/05 3:14 PM	6/29/05 12:00 AM	344.52	0.00	0.00	0.00	344.52	166.08	0.00	0.00	0.00	166.08
21044	Private Office	PO	344.98	344.98	0.00	0.00	0.00	6/14/05 3:02 PM	6/29/05 12:00 AM	78.82	0.00	0.00	0.00	78.82	41.27	0.00	0.00	0.00	41.27
22106	MultiPurpose Rm	MP	344.33	344.33	0.00	0.00	0.00	6/14/05 3:41 PM	6/29/05 12:00 AM	267.55	0.00	0.00	0.00	267.55	215.35	0.00	0.00	0.00	215.35
21187	Open Office	OO	345.18	345.18	0.00	0.00	0.00	6/14/05 2:50 PM	6/29/05 12:00 AM	99.82	0.00	0.00	0.00	99.82	92.38	0.00	0.00	0.00	92.38
22965	MultiPurpose Rm	MP	344.50	344.50	0.00	0.00	0.00	6/14/05 3:31 PM	6/29/05 12:00 AM	344.50	0.00	0.00	0.00	344.50	76.90	0.00	0.00	0.00	76.90
22075	MultiPurpose Rm	MP	344.53	344.53	0.00	0.00	0.00	6/14/05 3:29 PM	6/29/05 12:00 AM	343.00	0.00	0.00	0.00	343.00	86.33	0.00	0.00	0.00	86.33
22054	Private Office	PO	345.03	345.03	0.00	0.00	0.00	6/14/05 2:59 PM	6/29/05 12:00 AM	221.13	0.00	0.00	0.00	221.13	112.67	0.00	0.00	0.00	112.67
20873	Open Office	OO	345.12	345.12	0.00	0.00	0.00	6/14/05 2:54 PM	6/29/05 12:00 AM	330.18	0.00	0.00	0.00	330.18	163.47	0.00	0.00	0.00	163.47
23235	MultiPurpose Rm	MP	344.57	344.57	0.00	0.00	0.00	6/14/05 3:27 PM	6/29/05 12:00 AM	305.37	0.00	0.00	0.00	305.37	166.43	0.00	0.00	0.00	166.43

Normalized Data Logger Detail Building type:Office. Building size:10K to less than 25K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23139	Open Office	OO	240	53.21	0.00	0.00	0.00	53.21	43.59	0.00	0.00	0.00	43.59	18.08%
21264	MultiPurpose	MP	240	153.48	0.00	0.00	0.00	153.48	60.15	0.00	0.00	0.00	60.15	60.81%
23480	Private Office	PO	320	82.58	0.00	0.00	0.00	82.58	56.15	0.00	0.00	0.00	56.15	32.01%
21335	MultiPurpose	MP	160	125.38	0.00	0.00	0.00	125.38	34.79	0.00	0.00	0.00	34.79	72.25%
21515	Kitchen	K	80	168.00	0.00	0.00	0.00	168.00	93.10	0.00	0.00	0.00	93.10	44.58%
23449	Restroom	R	240	165.81	0.00	0.00	0.00	165.81	44.89	0.00	0.00	0.00	44.89	72.93%
20763	MultiPurpose	MP	480	168.00	0.00	0.00	0.00	168.00	103.92	0.00	0.00	0.00	103.92	38.14%
21440	Restroom	R	240	167.87	0.00	0.00	0.00	167.87	80.93	0.00	0.00	0.00	80.93	51.79%
21044	Private Office	PO	320	38.38	0.00	0.00	0.00	38.38	20.10	0.00	0.00	0.00	20.10	47.63%
22106	MultiPurpose	MP	800	130.54	0.00	0.00	0.00	130.54	105.07	0.00	0.00	0.00	105.07	19.51%
21187	Open Office	OO	480	48.58	0.00	0.00	0.00	48.58	44.96	0.00	0.00	0.00	44.96	7.45%
22965	MultiPurpose	MP	160	168.00	0.00	0.00	0.00	168.00	37.50	0.00	0.00	0.00	37.50	77.68%
22075	MultiPurpose	MP	720	167.25	0.00	0.00	0.00	167.25	42.10	0.00	0.00	0.00	42.10	74.83%
22054	Private Office	PO	240	107.67	0.00	0.00	0.00	107.67	54.86	0.00	0.00	0.00	54.86	49.05%
20873	Open Office	OO	640	160.73	0.00	0.00	0.00	160.73	79.57	0.00	0.00	0.00	79.57	50.49%
23235	MultiPurpose	MP	960	148.89	0.00	0.00	0.00	148.89	81.15	0.00	0.00	0.00	81.15	45.50%

Building Summary Totals Building type:Office. Building size:10K to less than 25K. Shifts:2

Building Summary Totals			Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	3	879	67	0	0	67	38	0	0	0	38
Restroom	R	2	480	80	0	0	80	30	0	0	0	30
Kitchen	K	1	80	13	0	0	13	7	0	0	0	7
Open Office	OO	3	1359	119	0	0	119	76	0	0	0	76
MultiPurpose Rm	MP	7	3521	534	0	0	534	234	0	0	0	234
Building Totals			6319	813	0	0	813	386	0	0	0	386