


Area Type Averages

Building type:Office. Building size:250K to less than 500K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Warehouse	W	32	100	96.07	0.00	0.00	0.00	96.07	61.77	0.00	0.00	0.00	61.77	35.70%
Office	O	9	100	125.73	0.00	0.00	0.00	125.73	59.47	0.00	0.00	0.00	59.47	52.70%
Conference	CN	1	100	40.22	0.00	0.00	0.00	40.22	16.51	0.00	0.00	0.00	16.51	58.95%
Building Average			4200	101.10	0.00			101.10	60.20	0.00			60.20	40.45%



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:250K to less than 500K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed					Installed		Removed		Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total		
21109	Office	D	332.58	332.58	0.00	0.00	0.00	9/07/05 8:31 PM	9/21/05 5:05 PM	121.43	0.00	0.00	0.00	121.43	84.90	0.00	0.00	0.00	84.90		
21026	Warehouse	W	332.63	332.63	0.00	0.00	0.00	9/07/05 8:26 PM	9/21/05 5:03 PM	167.52	0.00	0.00	0.00	167.52	128.45	0.00	0.00	0.00	128.45		
21147	Warehouse	W	332.62	332.62	0.00	0.00	0.00	9/07/05 8:28 PM	9/21/05 5:04 PM	182.10	0.00	0.00	0.00	182.10	125.67	0.00	0.00	0.00	125.67		
21130	Office	D	332.57	332.57	0.00	0.00	0.00	9/07/05 8:33 PM	9/21/05 5:06 PM	298.62	0.00	0.00	0.00	298.62	117.32	0.00	0.00	0.00	117.32		
21581	Warehouse	W	332.40	332.40	0.00	0.00	0.00	9/07/05 8:44 PM	9/21/05 5:07 PM	125.22	0.00	0.00	0.00	125.22	106.15	0.00	0.00	0.00	106.15		
21804	Warehouse	W	332.20	332.20	0.00	0.00	0.00	9/07/05 9:04 PM	9/21/05 5:15 PM	156.75	0.00	0.00	0.00	156.75	114.98	0.00	0.00	0.00	114.98		
22847	Warehouse	W	332.23	332.23	0.00	0.00	0.00	9/07/05 9:01 PM	9/21/05 5:14 PM	159.78	0.00	0.00	0.00	159.78	119.18	0.00	0.00	0.00	119.18		
21225	Warehouse	W	332.53	332.53	0.00	0.00	0.00	9/07/05 8:38 PM	9/21/05 5:09 PM	151.13	0.00	0.00	0.00	151.13	123.27	0.00	0.00	0.00	123.27		
22127	Office	D	332.57	332.57	0.00	0.00	0.00	9/07/05 8:36 PM	9/21/05 5:09 PM	167.35	0.00	0.00	0.00	167.35	139.22	0.00	0.00	0.00	139.22		
22729	Office	D	332.25	332.25	0.00	0.00	0.00	9/07/05 8:57 PM	9/21/05 5:11 PM	332.23	0.00	0.00	0.00	332.23	111.88	0.00	0.00	0.00	111.88		
21775	Office	D	333.40	333.40	0.00	0.00	0.00	9/07/05 8:51 PM	9/21/05 5:14 PM	333.35	0.00	0.00	0.00	333.35	148.45	0.00	0.00	0.00	148.45		
22128	Office	D	332.33	332.33	0.00	0.00	0.00	9/07/05 8:54 PM	9/21/05 5:13 PM	234.42	0.00	0.00	0.00	234.42	155.18	0.00	0.00	0.00	155.18		
22099	Warehouse	W	340.48	340.48	0.00	0.00	0.00	9/07/05 6:32 PM	9/21/05 11:00 PM	201.42	0.00	0.00	0.00	201.42	177.42	0.00	0.00	0.00	177.42		
22475	Conference	CN	335.52	335.52	0.00	0.00	0.00	9/07/05 6:23 PM	9/21/05 5:53 PM	80.33	0.00	0.00	0.00	80.33	32.97	0.00	0.00	0.00	32.97		
21973	Warehouse	W	335.43	335.43	0.00	0.00	0.00	9/07/05 6:29 PM	9/21/05 5:54 PM	132.15	0.00	0.00	0.00	132.15	121.85	0.00	0.00	0.00	121.85		
23848	Warehouse	W	335.37	335.37	0.00	0.00	0.00	9/07/05 6:35 PM	9/21/05 5:56 PM	131.23	0.00	0.00	0.00	131.23	117.03	0.00	0.00	0.00	117.03		
22777	Warehouse	W	335.47	335.47	0.00	0.00	0.00	9/07/05 6:29 PM	9/21/05 5:56 PM	162.70	0.00	0.00	0.00	162.70	116.43	0.00	0.00	0.00	116.43		
23823	Warehouse	W	335.35	335.35	0.00	0.00	0.00	9/07/05 6:38 PM	9/21/05 5:58 PM	113.27	0.00	0.00	0.00	113.27	108.67	0.00	0.00	0.00	108.67		
21488	Warehouse	W	335.08	335.08	0.00	0.00	0.00	9/07/05 7:20 PM	9/21/05 6:24 PM	117.27	0.00	0.00	0.00	117.27	89.03	0.00	0.00	0.00	89.03		
23308	Warehouse	W	312.30	312.30	0.00	0.00	0.00	9/08/05 4:37 PM	9/21/05 4:54 PM	312.28	0.00	0.00	0.00	312.28	142.72	0.00	0.00	0.00	142.72		
21016	Warehouse	W	335.10	335.10	0.00	0.00	0.00	9/07/05 7:18 PM	9/21/05 6:23 PM	92.90	0.00	0.00	0.00	92.90	52.77	0.00	0.00	0.00	52.77		
21591	Office	D	333.72	333.72	0.00	0.00	0.00	9/07/05 7:11 PM	9/21/05 4:53 PM	179.67	0.00	0.00	0.00	179.67	145.60	0.00	0.00	0.00	145.60		
23201	Warehouse	W	333.52	333.52	0.00	0.00	0.00	9/07/05 7:26 PM	9/21/05 4:56 PM	183.83	0.00	0.00	0.00	183.83	143.03	0.00	0.00	0.00	143.03		
24242	Warehouse	W	333.92	333.92	0.00	0.00	0.00	9/07/05 6:54 PM	9/21/05 4:48 PM	333.90	0.00	0.00	0.00	333.90	156.58	0.00	0.00	0.00	156.58		
21050	Warehouse	W	333.87	333.87	0.00	0.00	0.00	9/07/05 7:00 PM	9/21/05 4:51 PM	177.68	0.00	0.00	0.00	177.68	132.98	0.00	0.00	0.00	132.98		
21607	Office	D	333.77	333.77	0.00	0.00	0.00	9/07/05 7:07 PM	9/21/05 4:52 PM	333.72	0.00	0.00	0.00	333.72	121.62	0.00	0.00	0.00	121.62		
21117	Warehouse	W	333.77	333.77	0.00	0.00	0.00	9/07/05 7:14 PM	9/21/05 4:59 PM	173.52	0.00	0.00	0.00	173.52	130.98	0.00	0.00	0.00	130.98		
21434	Warehouse	W	333.58	333.58	0.00	0.00	0.00	9/07/05 7:22 PM	9/21/05 4:56 PM	333.57	0.00	0.00	0.00	333.57	65.80	0.00	0.00	0.00	65.80		
24334	Warehouse	W	333.88	333.88	0.00	0.00	0.00	9/07/05 6:57 PM	9/21/05 4:49 PM	178.90	0.00	0.00	0.00	178.90	124.70	0.00	0.00	0.00	124.70		
22181	Office	D	339.93	339.93	0.00	0.00	0.00	9/07/05 7:05 PM	9/21/05 11:00 PM	246.80	0.00	0.00	0.00	246.80	37.33	0.00	0.00	0.00	37.33		
22064	Warehouse	W	342.55	342.55	0.00	0.00	0.00	9/07/05 4:28 PM	9/21/05 11:00 PM	186.95	0.00	0.00	0.00	186.95	109.43	0.00	0.00	0.00	109.43		
22688	Warehouse	W	342.60	342.60	0.00	0.00	0.00	9/07/05 4:25 PM	9/21/05 11:00 PM	335.60	0.00	0.00	0.00	335.60	105.53	0.00	0.00	0.00	105.53		
24616	Warehouse	W	329.00	329.00	0.00	0.00	0.00	9/07/05 11:00 PM	9/21/05 3:59 PM	328.72	0.00	0.00	0.00	328.72	148.68	0.00	0.00	0.00	148.68		
23873	Warehouse	W	335.57	335.57	0.00	0.00	0.00	9/07/05 4:31 PM	9/21/05 4:04 PM	173.97	0.00	0.00	0.00	173.97	140.60	0.00	0.00	0.00	140.60		
21349	Warehouse	W	335.52	335.52	0.00	0.00	0.00	9/07/05 4:35 PM	9/21/05 4:05 PM	318.80	0.00	0.00	0.00	318.80	142.02	0.00	0.00	0.00	142.02		
24154	Warehouse	W	331.92	331.92	0.00	0.00	0.00	9/07/05 8:14 PM	9/21/05 4:08 PM	169.18	0.00	0.00	0.00	169.18	154.75	0.00	0.00	0.00	154.75		
21400	Warehouse	W	335.40	335.40	0.00	0.00	0.00	9/07/05 4:46 PM	9/21/05 4:09 PM	173.70	0.00	0.00	0.00	173.70	158.63	0.00	0.00	0.00	158.63		
23398	Warehouse	W	335.18	335.18	0.00	0.00	0.00	9/07/05 5:06 PM	9/21/05 4:16 PM	162.63	0.00	0.00	0.00	162.63	148.87	0.00	0.00	0.00	148.87		
24055	Warehouse	W	331.98	331.98	0.00	0.00	0.00	9/07/05 8:12 PM	9/21/05 4:10 PM	114.30	0.00	0.00	0.00	114.30	101.87	0.00	0.00	0.00	101.87		
24152	Warehouse	W	311.63	311.63	0.00	0.00	0.00	9/08/05 4:34 PM	9/21/05 4:11 PM	192.98	0.00	0.00	0.00	192.98	122.72	0.00	0.00	0.00	122.72		
23825	Warehouse	W	335.22	335.22	0.00	0.00	0.00	9/07/05 5:04 PM	9/21/05 4:16 PM	207.53	0.00	0.00	0.00	207.53	114.27	0.00	0.00	0.00	114.27		
24243	Warehouse	W	335.25	335.25	0.00	0.00	0.00	9/07/05 4:59 PM	9/21/05 4:13 PM	137.42	0.00	0.00	0.00	137.42	72.40	0.00	0.00	0.00	72.40		

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
21109	Office	O	100	61.34	0.00	0.00	0.00	61.34	42.89	0.00	0.00	0.00	42.89	30.08%
21026	Warehouse	W	100	84.61	0.00	0.00	0.00	84.61	64.88	0.00	0.00	0.00	64.88	23.32%
21147	Warehouse	W	100	91.98	0.00	0.00	0.00	91.98	63.47	0.00	0.00	0.00	63.47	31.00%
21130	Office	O	100	150.85	0.00	0.00	0.00	150.85	59.26	0.00	0.00	0.00	59.26	60.72%
21581	Warehouse	W	100	63.29	0.00	0.00	0.00	63.29	53.65	0.00	0.00	0.00	53.65	15.23%
21804	Warehouse	W	100	79.27	0.00	0.00	0.00	79.27	58.15	0.00	0.00	0.00	58.15	26.64%
22847	Warehouse	W	100	80.80	0.00	0.00	0.00	80.80	60.27	0.00	0.00	0.00	60.27	25.41%
21225	Warehouse	W	100	76.35	0.00	0.00	0.00	76.35	62.28	0.00	0.00	0.00	62.28	18.43%
22127	Office	O	100	84.54	0.00	0.00	0.00	84.54	70.33	0.00	0.00	0.00	70.33	16.81%
22729	Office	O	100	167.99	0.00	0.00	0.00	167.99	56.57	0.00	0.00	0.00	56.57	66.33%
21775	Office	O	100	167.97	0.00	0.00	0.00	167.97	74.80	0.00	0.00	0.00	74.80	55.47%
22128	Office	O	100	118.50	0.00	0.00	0.00	118.50	78.45	0.00	0.00	0.00	78.45	33.80%
22099	Warehouse	W	100	99.38	0.00	0.00	0.00	99.38	87.54	0.00	0.00	0.00	87.54	11.91%
22475	Conference	CN	100	40.22	0.00	0.00	0.00	40.22	16.51	0.00	0.00	0.00	16.51	58.95%
21973	Warehouse	W	100	66.19	0.00	0.00	0.00	66.19	61.03	0.00	0.00	0.00	61.03	7.80%
23848	Warehouse	W	100	65.74	0.00	0.00	0.00	65.74	58.63	0.00	0.00	0.00	58.63	10.82%
22777	Warehouse	W	100	81.48	0.00	0.00	0.00	81.48	58.31	0.00	0.00	0.00	58.31	28.44%
23823	Warehouse	W	100	56.74	0.00	0.00	0.00	56.74	54.44	0.00	0.00	0.00	54.44	4.05%
21488	Warehouse	W	100	58.79	0.00	0.00	0.00	58.79	44.64	0.00	0.00	0.00	44.64	24.07%
23308	Warehouse	W	100	167.99	0.00	0.00	0.00	167.99	76.77	0.00	0.00	0.00	76.77	54.30%
21016	Warehouse	W	100	46.57	0.00	0.00	0.00	46.57	26.45	0.00	0.00	0.00	26.45	43.20%
21591	Office	O	100	90.45	0.00	0.00	0.00	90.45	73.30	0.00	0.00	0.00	73.30	18.96%
23201	Warehouse	W	100	92.60	0.00	0.00	0.00	92.60	72.05	0.00	0.00	0.00	72.05	22.19%
24242	Warehouse	W	100	167.99	0.00	0.00	0.00	167.99	78.78	0.00	0.00	0.00	78.78	53.10%
21050	Warehouse	W	100	89.41	0.00	0.00	0.00	89.41	66.92	0.00	0.00	0.00	66.92	25.15%
21607	Office	O	100	167.97	0.00	0.00	0.00	167.97	61.22	0.00	0.00	0.00	61.22	63.55%
21117	Warehouse	W	100	87.34	0.00	0.00	0.00	87.34	65.93	0.00	0.00	0.00	65.93	24.51%
21434	Warehouse	W	100	167.99	0.00	0.00	0.00	167.99	33.14	0.00	0.00	0.00	33.14	80.27%
24334	Warehouse	W	100	90.02	0.00	0.00	0.00	90.02	62.75	0.00	0.00	0.00	62.75	30.29%
22181	Office	O	100	121.97	0.00	0.00	0.00	121.97	18.45	0.00	0.00	0.00	18.45	84.87%
22064	Warehouse	W	100	91.69	0.00	0.00	0.00	91.69	53.67	0.00	0.00	0.00	53.67	41.47%
22688	Warehouse	W	100	164.57	0.00	0.00	0.00	164.57	51.75	0.00	0.00	0.00	51.75	68.55%
24616	Warehouse	W	100	167.86	0.00	0.00	0.00	167.86	75.92	0.00	0.00	0.00	75.92	54.77%
23873	Warehouse	W	100	87.10	0.00	0.00	0.00	87.10	70.39	0.00	0.00	0.00	70.39	19.18%
21349	Warehouse	W	100	159.63	0.00	0.00	0.00	159.63	71.11	0.00	0.00	0.00	71.11	55.45%
24154	Warehouse	W	100	85.63	0.00	0.00	0.00	85.63	78.33	0.00	0.00	0.00	78.33	8.53%
21400	Warehouse	W	100	87.01	0.00	0.00	0.00	87.01	79.46	0.00	0.00	0.00	79.46	8.68%
23398	Warehouse	W	100	81.51	0.00	0.00	0.00	81.51	74.61	0.00	0.00	0.00	74.61	8.47%
24055	Warehouse	W	100	57.84	0.00	0.00	0.00	57.84	51.55	0.00	0.00	0.00	51.55	10.87%
24152	Warehouse	W	100	104.04	0.00	0.00	0.00	104.04	66.16	0.00	0.00	0.00	66.16	36.41%
23825	Warehouse	W	100	104.01	0.00	0.00	0.00	104.01	57.27	0.00	0.00	0.00	57.27	44.94%
24243	Warehouse	W	100	68.86	0.00	0.00	0.00	68.86	36.28	0.00	0.00	0.00	36.28	47.31%

Building Summary Totals Building type:Office. Building size:250K to less than 500K. Shifts:3 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Warehouse	W	32	3200	307	0	0	0	307	198	0	0	0	198
Office	O	9	900	113	0	0	0	113	54	0	0	0	54
Conference	CN	1	100	4	0	0	0	4	2	0	0	0	2
Building Totals			4200	425			0	425	253			0	253