


# Area Type Averages

Building type:Retail. Building size:50K to less than 100K. Shifts:2

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	1	87	99.22	0.00	0.00	0.00	99.22	83.45	0.00	0.00	0.00	83.45	15.89%
Restroom	R	3	87	133.97	0.00	0.00	0.00	133.97	42.30	0.00	0.00	0.00	42.30	68.43%
Storage	S	1	87	16.03	0.00	0.00	0.00	16.03	5.75	0.00	0.00	0.00	5.75	64.13%
Hallway	H	1	105	102.74	0.00	0.00	0.00	102.74	82.05	0.00	0.00	0.00	82.05	20.14%
Mechanical Room /	MR	1	87	17.41	0.00	0.00	0.00	17.41	1.54	0.00	0.00	0.00	1.54	91.15%
Stock Room	ST	2	114	94.42	0.00	0.00	0.00	94.42	14.44	0.00	0.00	0.00	14.44	84.71%
Office	O	4	92	61.32	0.00	0.00	0.00	61.32	32.28	0.00	0.00	0.00	32.28	47.36%
Building Average			1223	82.90			0.00	82.90	34.93			0.00	34.93	57.86%



Hours per Week for each Area Type

## Data Logger Detail Building type:Retail. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20250	Office	O	826.92	826.92	0.00	0.00	0.00	7/26/05 1:06 PM	8/30/05 12:00 AM	170.78	0.00	0.00	0.00	170.78	101.62	0.00	0.00	0.00	101.62
20416	Office	O	827.38	827.38	0.00	0.00	0.00	7/26/05 12:38 PM	8/30/05 12:00 AM	101.00	0.00	0.00	0.00	101.00	50.43	0.00	0.00	0.00	50.43
20386	Meeting Rooms	M	527.78	527.78	0.00	0.00	0.00	7/26/05 1:41 PM	8/17/05 1:27 PM	311.70	0.00	0.00	0.00	311.70	262.17	0.00	0.00	0.00	262.17
20204	Storage	S	826.50	826.50	0.00	0.00	0.00	7/26/05 1:31 PM	8/30/05 12:00 AM	78.85	0.00	0.00	0.00	78.85	28.30	0.00	0.00	0.00	28.30
20042	Office	O	479.93	479.93	0.00	0.00	0.00	7/26/05 12:38 PM	8/15/05 12:33 PM	479.92	0.00	0.00	0.00	479.92	239.60	0.00	0.00	0.00	239.60
20030	Restroom	R	827.33	827.33	0.00	0.00	0.00	7/26/05 12:41 PM	8/30/05 12:00 AM	575.97	0.00	0.00	0.00	575.97	54.03	0.00	0.00	0.00	54.03
20271	Restroom	R	827.37	827.37	0.00	0.00	0.00	7/26/05 12:39 PM	8/30/05 12:00 AM	575.98	0.00	0.00	0.00	575.98	270.80	0.00	0.00	0.00	270.80
20412	Mechanical Room / Storage	MR	824.67	824.67	0.00	0.00	0.00	7/26/05 3:21 PM	8/30/05 12:00 AM	85.45	0.00	0.00	0.00	85.45	7.55	0.00	0.00	0.00	7.55
20206	Restroom	R	574.37	574.37	0.00	0.00	0.00	7/26/05 12:40 PM	8/19/05 11:01 AM	574.35	0.00	0.00	0.00	574.35	208.35	0.00	0.00	0.00	208.35
20186	Office	O	826.50	826.50	0.00	0.00	0.00	7/26/05 1:31 PM	8/30/05 12:00 AM	108.57	0.00	0.00	0.00	108.57	70.63	0.00	0.00	0.00	70.63
20184	Stock Room	ST	826.15	826.15	0.00	0.00	0.00	7/26/05 1:52 PM	8/30/05 12:00 AM	352.88	0.00	0.00	0.00	352.88	0.00	0.00	0.00	0.00	0.00
20422	Hallway	H	480.67	480.67	0.00	0.00	0.00	7/26/05 1:49 PM	8/15/05 2:28 PM	293.95	0.00	0.00	0.00	293.95	234.75	0.00	0.00	0.00	234.75
20113	Stock Room	ST	826.28	826.28	0.00	0.00	0.00	7/26/05 1:44 PM	8/30/05 12:00 AM	575.82	0.00	0.00	0.00	575.82	141.98	0.00	0.00	0.00	141.98

## Normalized Data Logger Detail Building type:Retail. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20250	Office	O	87	34.70	0.00	0.00	0.00	34.70	20.64	0.00	0.00	0.00	20.64	40.52%
20416	Office	O	87	20.51	0.00	0.00	0.00	20.51	10.24	0.00	0.00	0.00	10.24	50.07%
20386	Meeting Rooms	M	87	99.22	0.00	0.00	0.00	99.22	83.45	0.00	0.00	0.00	83.45	15.89%
20204	Storage	S	87	16.03	0.00	0.00	0.00	16.03	5.75	0.00	0.00	0.00	5.75	64.13%
20042	Office	O	105	167.99	0.00	0.00	0.00	167.99	83.87	0.00	0.00	0.00	83.87	50.07%
20030	Restroom	R	87	116.96	0.00	0.00	0.00	116.96	10.97	0.00	0.00	0.00	10.97	90.62%
20271	Restroom	R	87	116.96	0.00	0.00	0.00	116.96	54.99	0.00	0.00	0.00	54.99	52.98%
20412	Mechanical	MR	87	17.41	0.00	0.00	0.00	17.41	1.54	0.00	0.00	0.00	1.54	91.15%
20206	Restroom	R	87	168.00	0.00	0.00	0.00	168.00	60.94	0.00	0.00	0.00	60.94	63.73%
20186	Office	O	87	22.07	0.00	0.00	0.00	22.07	14.36	0.00	0.00	0.00	14.36	34.93%
20184	Stock Room	ST	114	71.76	0.00	0.00	0.00	71.76	0.00	0.00	0.00	0.00	0.00	00.00%
20422	Hallway	H	105	102.74	0.00	0.00	0.00	102.74	82.05	0.00	0.00	0.00	82.05	20.14%
20113	Stock Room	ST	114	117.08	0.00	0.00	0.00	117.08	28.87	0.00	0.00	0.00	28.87	75.34%

## Building Summary Totals Building type:Retail. Building size:50K to less than 100K. Shifts:2

Building Summary Totals			Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	1	87	9	0	0	0	9	7	0	0	0	7
Restroom	R	3	261	35	0	0	0	35	11	0	0	0	11
Storage	S	1	87	1	0	0	0	1	1	0	0	0	1
Hallway	H	1	105	11	0	0	0	11	9	0	0	0	9
Mechanical Room /	MR	1	87	2	0	0	0	2	0	0	0	0	0
Stock Room	ST	2	228	22	0	0	0	22	3	0	0	0	3
Office	O	4	368	23	0	0	0	23	12	0	0	0	12
Building Totals			1223	101	0	0	0	101	43	0	0	0	43