


Area Type Averages

Building type:Warehouse. Building size:more than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Stock Aisle	SA	8	458	152.08	0.00	0.00	0.00	152.08	34.29	0.00	0.00	0.00	34.29	77.45%
Open Bay	OB	5	458	134.94	0.00	0.00	0.00	134.94	53.24	0.00	0.00	0.00	53.24	60.55%
Building Average			5954	145.49			0.00	145.49	41.58			0.00	41.58	71.42%



Hours per Week for each Area Type

Data Logger Detail Building type:Warehouse. Building size:more than 1,000K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
24830	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	224.70	0.00	0.00	0.00	224.70	29.78	0.00	0.00	0.00	29.78
24834	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	224.53	0.00	0.00	0.00	224.53	28.20	0.00	0.00	0.00	28.20
24827	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	224.90	0.00	0.00	0.00	224.90	6.93	0.00	0.00	0.00	6.93
24822	Open Bay	OB	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	224.73	0.00	0.00	0.00	224.73	85.23	0.00	0.00	0.00	85.23
24988	Open Bay	OB	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	140.35	0.00	0.00	0.00	140.35	62.10	0.00	0.00	0.00	62.10
24829	Open Bay	OB	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	225.78	0.00	0.00	0.00	225.78	111.33	0.00	0.00	0.00	111.33
24842	Stock Aisle	SA	75.90	75.90	0.00	0.00	0.00	11/21/05 12:00	11/24/05 3:53 AM	61.43	0.00	0.00	0.00	61.43	10.20	0.00	0.00	0.00	10.20
24985	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	187.15	0.00	0.00	0.00	187.15	49.03	0.00	0.00	0.00	49.03
24856	Open Bay	OB	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	143.28	0.00	0.00	0.00	143.28	20.77	0.00	0.00	0.00	20.77
24858	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	226.07	0.00	0.00	0.00	226.07	34.53	0.00	0.00	0.00	34.53
24841	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	227.77	0.00	0.00	0.00	227.77	125.30	0.00	0.00	0.00	125.30
24872	Stock Aisle	SA	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	228.78	0.00	0.00	0.00	228.78	85.88	0.00	0.00	0.00	85.88
24839	Open Bay	OB	240.02	240.02	0.00	0.00	0.00	11/21/05 12:00	12/01/05 12:00	229.77	0.00	0.00	0.00	229.77	100.88	0.00	0.00	0.00	100.88

Normalized Data Logger Detail Building type:Warehouse. Building size:more than 1,000K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24830	Stock Aisle	SA	458	157.28	0.00	0.00	0.00	157.28	20.85	0.00	0.00	0.00	20.85	86.74%
24834	Stock Aisle	SA	458	157.16	0.00	0.00	0.00	157.16	19.74	0.00	0.00	0.00	19.74	87.44%
24827	Stock Aisle	SA	458	157.42	0.00	0.00	0.00	157.42	4.85	0.00	0.00	0.00	4.85	96.92%
24822	Open Bay	OB	458	157.30	0.00	0.00	0.00	157.30	59.66	0.00	0.00	0.00	59.66	62.07%
24988	Open Bay	OB	458	98.24	0.00	0.00	0.00	98.24	43.47	0.00	0.00	0.00	43.47	55.75%
24829	Open Bay	OB	458	158.04	0.00	0.00	0.00	158.04	77.93	0.00	0.00	0.00	77.93	50.69%
24842	Stock Aisle	SA	458	135.98	0.00	0.00	0.00	135.98	22.58	0.00	0.00	0.00	22.58	83.39%
24985	Stock Aisle	SA	458	131.00	0.00	0.00	0.00	131.00	34.32	0.00	0.00	0.00	34.32	73.80%
24856	Open Bay	OB	458	100.29	0.00	0.00	0.00	100.29	14.54	0.00	0.00	0.00	14.54	85.50%
24858	Stock Aisle	SA	458	158.24	0.00	0.00	0.00	158.24	24.17	0.00	0.00	0.00	24.17	84.73%
24841	Stock Aisle	SA	458	159.43	0.00	0.00	0.00	159.43	87.70	0.00	0.00	0.00	87.70	44.99%
24872	Stock Aisle	SA	458	160.14	0.00	0.00	0.00	160.14	60.11	0.00	0.00	0.00	60.11	62.46%
24839	Open Bay	OB	458	160.83	0.00	0.00	0.00	160.83	70.61	0.00	0.00	0.00	70.61	56.10%

Building Summary Totals Building type:Warehouse. Building size:more than 1,000K. Shifts:3

Building Summary Totals			Lights On KWHR					Occupied KWHR					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Stock Aisle	SA	8	3664	557	0	0	0	557	126	0	0	0	126
Open Bay	OB	5	2290	309	0	0	0	309	122	0	0	0	122
Building Totals			5954	866			0	866	248			0	248