


Area Type Averages

Building type:Warehouse. Building size:100K to less than 250K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Warehouse	W	11	400	167.98	0.00	0.00	0.00	167.98	102.22	0.00	0.00	0.00	102.22	39.15%
Building Average		4400	167.98	0.00			167.98	102.22	0.00			102.22	39.15%	



Hours per Week for each Area Type

Data Logger Detail Building type:Warehouse. Building size:100K to less than 250K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20299	Warehouse	W	345.83	345.83	0.00	0.00	0.00	9/29/05 6:53 PM	10/14/05 4:42 AM	345.82	0.00	0.00	0.00	345.82	306.55	0.00	0.00	0.00	306.55
20122	Warehouse	W	350.40	350.40	0.00	0.00	0.00	9/29/05 6:40 PM	10/14/05 9:03 AM	350.38	0.00	0.00	0.00	350.38	204.58	0.00	0.00	0.00	204.58
20443	Warehouse	W	364.32	364.32	0.00	0.00	0.00	9/29/05 6:42 PM	10/14/05 11:00	364.02	0.00	0.00	0.00	364.02	234.00	0.00	0.00	0.00	234.00
20127	Warehouse	W	298.05	298.05	0.00	0.00	0.00	9/29/05 6:58 PM	10/12/05 5:00 AM	297.93	0.00	0.00	0.00	297.93	267.40	0.00	0.00	0.00	267.40
20442	Warehouse	W	261.43	261.43	0.00	0.00	0.00	9/29/05 6:59 PM	10/10/05 4:24 PM	261.42	0.00	0.00	0.00	261.42	221.88	0.00	0.00	0.00	221.88
20436	Warehouse	W	364.23	364.23	0.00	0.00	0.00	9/29/05 6:47 PM	10/14/05 11:00	364.23	0.00	0.00	0.00	364.23	72.60	0.00	0.00	0.00	72.60
20018	Warehouse	W	317.70	317.70	0.00	0.00	0.00	9/29/05 6:56 PM	10/13/05 12:37	317.68	0.00	0.00	0.00	317.68	239.80	0.00	0.00	0.00	239.80
20275	Warehouse	W	364.07	364.07	0.00	0.00	0.00	9/29/05 6:57 PM	10/14/05 11:00	364.07	0.00	0.00	0.00	364.07	173.58	0.00	0.00	0.00	173.58
20123	Warehouse	W	364.12	364.12	0.00	0.00	0.00	9/29/05 6:54 PM	10/14/05 11:00	364.12	0.00	0.00	0.00	364.12	228.12	0.00	0.00	0.00	228.12
20391	Warehouse	W	364.15	364.15	0.00	0.00	0.00	9/29/05 6:52 PM	10/14/05 11:00	364.15	0.00	0.00	0.00	364.15	255.52	0.00	0.00	0.00	255.52
20227	Warehouse	W	364.38	364.38	0.00	0.00	0.00	9/29/05 6:38 PM	10/14/05 11:00	364.38	0.00	0.00	0.00	364.38	27.42	0.00	0.00	0.00	27.42

Normalized Data Logger Detail Building type:Warehouse. Building size:100K to less than 250K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20299	Warehouse	W	400	167.99	0.00	0.00	0.00	167.99	148.92	0.00	0.00	0.00	148.92	11.35%
20122	Warehouse	W	400	167.99	0.00	0.00	0.00	167.99	98.09	0.00	0.00	0.00	98.09	41.61%
20443	Warehouse	W	400	167.86	0.00	0.00	0.00	167.86	107.91	0.00	0.00	0.00	107.91	35.71%
20127	Warehouse	W	400	167.93	0.00	0.00	0.00	167.93	150.72	0.00	0.00	0.00	150.72	10.25%
20442	Warehouse	W	400	167.99	0.00	0.00	0.00	167.99	142.58	0.00	0.00	0.00	142.58	15.13%
20436	Warehouse	W	400	168.00	0.00	0.00	0.00	168.00	33.49	0.00	0.00	0.00	33.49	80.07%
20018	Warehouse	W	400	167.99	0.00	0.00	0.00	167.99	126.81	0.00	0.00	0.00	126.81	24.51%
20275	Warehouse	W	400	168.00	0.00	0.00	0.00	168.00	80.10	0.00	0.00	0.00	80.10	52.32%
20123	Warehouse	W	400	168.00	0.00	0.00	0.00	168.00	105.25	0.00	0.00	0.00	105.25	37.35%
20391	Warehouse	W	400	168.00	0.00	0.00	0.00	168.00	117.88	0.00	0.00	0.00	117.88	29.83%
20227	Warehouse	W	400	168.00	0.00	0.00	0.00	168.00	12.64	0.00	0.00	0.00	12.64	92.48%

Building Summary Totals Building type:Warehouse. Building size:100K to less than 250K. Shifts:3

Building Summary Totals			Lights On KwHR						Occupied KwHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Warehouse	W	11	4400	739	0	0	739	450	0	0	0	450	
Building Totals			4400	739			739	450				450	