


# Area Type Averages

Building type:Warehouse. Building size:10K to less than 25K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Warehouse	W	5	458	112.68	0.00	0.00	0.00	112.68	38.79	0.00	0.00	0.00	38.79	65.58%
Building Average			2290	112.68	0.00			112.68	38.79	0.00			38.79	65.58%



Hours per Week for each Area Type

## Data Logger Detail Building type:Warehouse. Building size:10K to less than 25K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
22466	Warehouse	W	476.60	476.60	0.00	0.00	0.00	9/30/05 12:15 PM	10/20/05 8:50 AM	321.48	0.00	0.00	0.00	321.48	94.05	0.00	0.00	0.00	94.05
21896	Warehouse	W	476.58	476.58	0.00	0.00	0.00	9/30/05 12:12 PM	10/20/05 8:46 AM	321.60	0.00	0.00	0.00	321.60	167.50	0.00	0.00	0.00	167.50
21215	Warehouse	W	491.68	491.68	0.00	0.00	0.00	9/30/05 12:20 PM	10/21/05 12:00	321.63	0.00	0.00	0.00	321.63	159.77	0.00	0.00	0.00	159.77
24244	Warehouse	W	476.47	476.47	0.00	0.00	0.00	9/30/05 12:18 PM	10/20/05 8:45 AM	321.62	0.00	0.00	0.00	321.62	41.33	0.00	0.00	0.00	41.33
24280	Warehouse	W	476.57	476.57	0.00	0.00	0.00	9/30/05 12:16 PM	10/20/05 8:49 AM	321.65	0.00	0.00	0.00	321.65	92.38	0.00	0.00	0.00	92.38

## Normalized Data Logger Detail Building type:Warehouse. Building size:10K to less than 25K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
22466	Warehouse	W	458	113.32	0.00	0.00	0.00	113.32	33.15	0.00	0.00	0.00	33.15	70.75%
21896	Warehouse	W	458	113.37	0.00	0.00	0.00	113.37	59.05	0.00	0.00	0.00	59.05	47.91%
21215	Warehouse	W	458	109.90	0.00	0.00	0.00	109.90	54.59	0.00	0.00	0.00	54.59	50.33%
24244	Warehouse	W	458	113.40	0.00	0.00	0.00	113.40	14.57	0.00	0.00	0.00	14.57	87.15%
24280	Warehouse	W	458	113.39	0.00	0.00	0.00	113.39	32.57	0.00	0.00	0.00	32.57	71.28%

## Building Summary Totals Building type:Warehouse. Building size:10K to less than 25K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Warehouse	W	5	2290	258	0	0	0	258	89	0	0	0	89
Building Totals			2290	258			0	258	89			0	89