


# Area Type Averages

Building type:Warehouse. Building size:500K to less than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav		
Warehouse	W	44	850	164.19	0.00	0.00	0.00	164.19	38.25	0.00	0.00	0.00	38.25	76.70%	
Building Average		37400	164.19				0.00	164.19	38.25				0.00	38.25	76.70%



Hours per Week for each Area Type

Data Logger Detail Building type:Warehouse. Building size:500K to less than 1,000K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed						Lights On						Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
24690	Warehouse	W	159.53	159.53	0.00	0.00	0.00	11/02/05 5:29 PM	11/09/05 9:00 AM	5.20	0.00	0.00	0.00	5.20	1.97	0.00	0.00	0.00	1.97
21805	Warehouse	W	159.40	159.40	0.00	0.00	0.00	11/02/05 5:37 PM	11/09/05 9:00 AM	159.40	0.00	0.00	0.00	159.40	90.77	0.00	0.00	0.00	90.77
22992	Warehouse	W	159.10	159.10	0.00	0.00	0.00	11/02/05 5:55 PM	11/09/05 9:00 AM	159.10	0.00	0.00	0.00	159.10	43.03	0.00	0.00	0.00	43.03
22378	Warehouse	W	159.13	159.13	0.00	0.00	0.00	11/02/05 5:53 PM	11/09/05 9:00 AM	159.13	0.00	0.00	0.00	159.13	28.10	0.00	0.00	0.00	28.10
23394	Warehouse	W	126.57	126.57	0.00	0.00	0.00	11/03/05 9:57 AM	11/08/05 4:30 PM	126.57	0.00	0.00	0.00	126.57	39.60	0.00	0.00	0.00	39.60
22988	Warehouse	W	158.85	158.85	0.00	0.00	0.00	11/02/05 6:10 PM	11/09/05 9:00 AM	158.85	0.00	0.00	0.00	158.85	26.52	0.00	0.00	0.00	26.52
24700	Warehouse	W	159.30	159.30	0.00	0.00	0.00	11/02/05 5:43 PM	11/09/05 9:00 AM	159.30	0.00	0.00	0.00	159.30	53.23	0.00	0.00	0.00	53.23
22825	Warehouse	W	126.67	126.67	0.00	0.00	0.00	11/03/05 9:51 AM	11/08/05 4:30 PM	126.67	0.00	0.00	0.00	126.67	25.07	0.00	0.00	0.00	25.07
20974	Warehouse	W	158.98	158.98	0.00	0.00	0.00	11/02/05 6:02 PM	11/09/05 9:00 AM	158.98	0.00	0.00	0.00	158.98	21.70	0.00	0.00	0.00	21.70
22506	Warehouse	W	159.55	159.55	0.00	0.00	0.00	11/02/05 5:28 PM	11/09/05 9:00 AM	159.55	0.00	0.00	0.00	159.55	27.63	0.00	0.00	0.00	27.63
21174	Warehouse	W	159.57	159.57	0.00	0.00	0.00	11/02/05 5:27 PM	11/09/05 9:00 AM	159.57	0.00	0.00	0.00	159.57	34.30	0.00	0.00	0.00	34.30
22279	Warehouse	W	159.60	159.60	0.00	0.00	0.00	11/02/05 5:25 PM	11/09/05 9:00 AM	159.60	0.00	0.00	0.00	159.60	38.77	0.00	0.00	0.00	38.77
21996	Warehouse	W	159.63	159.63	0.00	0.00	0.00	11/02/05 5:23 PM	11/09/05 9:00 AM	159.63	0.00	0.00	0.00	159.63	39.37	0.00	0.00	0.00	39.37
24042	Warehouse	W	159.70	159.70	0.00	0.00	0.00	11/02/05 5:19 PM	11/09/05 9:00 AM	159.68	0.00	0.00	0.00	159.68	11.98	0.00	0.00	0.00	11.98
20979	Warehouse	W	159.68	159.68	0.00	0.00	0.00	11/02/05 5:20 PM	11/09/05 9:00 AM	159.68	0.00	0.00	0.00	159.68	36.88	0.00	0.00	0.00	36.88
23593	Warehouse	W	158.60	158.60	0.00	0.00	0.00	11/02/05 6:25 PM	11/09/05 9:00 AM	158.60	0.00	0.00	0.00	158.60	55.67	0.00	0.00	0.00	55.67
20787	Warehouse	W	159.35	159.35	0.00	0.00	0.00	11/02/05 5:40 PM	11/09/05 9:00 AM	159.35	0.00	0.00	0.00	159.35	37.33	0.00	0.00	0.00	37.33
21474	Warehouse	W	159.42	159.42	0.00	0.00	0.00	11/02/05 5:36 PM	11/09/05 9:00 AM	159.42	0.00	0.00	0.00	159.42	118.65	0.00	0.00	0.00	118.65
23886	Warehouse	W	159.45	159.45	0.00	0.00	0.00	11/02/05 5:34 PM	11/09/05 9:00 AM	159.45	0.00	0.00	0.00	159.45	121.02	0.00	0.00	0.00	121.02
23728	Warehouse	W	126.47	126.47	0.00	0.00	0.00	11/03/05 10:03	11/08/05 4:30 PM	126.47	0.00	0.00	0.00	126.47	26.13	0.00	0.00	0.00	26.13
23650	Warehouse	W	126.48	126.48	0.00	0.00	0.00	11/03/05 10:02	11/08/05 4:30 PM	126.48	0.00	0.00	0.00	126.48	27.02	0.00	0.00	0.00	27.02
23717	Warehouse	W	126.45	126.45	0.00	0.00	0.00	11/03/05 10:04	11/08/05 4:30 PM	126.45	0.00	0.00	0.00	126.45	34.12	0.00	0.00	0.00	34.12
21371	Warehouse	W	159.33	159.33	0.00	0.00	0.00	11/02/05 5:41 PM	11/09/05 9:00 AM	157.20	0.00	0.00	0.00	157.20	40.73	0.00	0.00	0.00	40.73
22905	Warehouse	W	159.28	159.28	0.00	0.00	0.00	11/02/05 5:44 PM	11/09/05 9:00 AM	159.18	0.00	0.00	0.00	159.18	23.97	0.00	0.00	0.00	23.97
20943	Warehouse	W	159.27	159.27	0.00	0.00	0.00	11/02/05 5:45 PM	11/09/05 9:00 AM	159.10	0.00	0.00	0.00	159.10	19.97	0.00	0.00	0.00	19.97
21980	Warehouse	W	158.63	158.63	0.00	0.00	0.00	11/02/05 6:23 PM	11/09/05 9:00 AM	158.63	0.00	0.00	0.00	158.63	14.40	0.00	0.00	0.00	14.40
21354	Warehouse	W	126.55	126.55	0.00	0.00	0.00	11/03/05 9:58 AM	11/08/05 4:30 PM	126.55	0.00	0.00	0.00	126.55	9.27	0.00	0.00	0.00	9.27
21005	Warehouse	W	158.65	158.65	0.00	0.00	0.00	11/02/05 6:22 PM	11/09/05 9:00 AM	158.62	0.00	0.00	0.00	158.62	16.07	0.00	0.00	0.00	16.07
22831	Warehouse	W	158.67	158.67	0.00	0.00	0.00	11/02/05 6:21 PM	11/09/05 9:00 AM	158.57	0.00	0.00	0.00	158.57	15.53	0.00	0.00	0.00	15.53
23561	Warehouse	W	158.68	158.68	0.00	0.00	0.00	11/02/05 6:20 PM	11/09/05 9:00 AM	158.55	0.00	0.00	0.00	158.55	18.83	0.00	0.00	0.00	18.83
23325	Warehouse	W	158.70	158.70	0.00	0.00	0.00	11/02/05 6:19 PM	11/09/05 9:00 AM	158.70	0.00	0.00	0.00	158.70	15.93	0.00	0.00	0.00	15.93
21702	Warehouse	W	158.87	158.87	0.00	0.00	0.00	11/02/05 6:09 PM	11/09/05 9:00 AM	158.78	0.00	0.00	0.00	158.78	16.47	0.00	0.00	0.00	16.47
21442	Warehouse	W	159.18	159.18	0.00	0.00	0.00	11/02/05 5:50 PM	11/09/05 9:00 AM	157.45	0.00	0.00	0.00	157.45	0.00	0.00	0.00	0.00	0.00
20683	Warehouse	W	159.17	159.17	0.00	0.00	0.00	11/02/05 5:51 PM	11/09/05 9:00 AM	159.13	0.00	0.00	0.00	159.13	15.17	0.00	0.00	0.00	15.17
21544	Warehouse	W	158.90	158.90	0.00	0.00	0.00	11/02/05 6:07 PM	11/09/05 9:00 AM	158.90	0.00	0.00	0.00	158.90	13.73	0.00	0.00	0.00	13.73
21761	Warehouse	W	158.95	158.95	0.00	0.00	0.00	11/02/05 6:04 PM	11/09/05 9:00 AM	158.95	0.00	0.00	0.00	158.95	14.17	0.00	0.00	0.00	14.17
22498	Warehouse	W	126.63	126.63	0.00	0.00	0.00	11/03/05 9:53 AM	11/08/05 4:30 PM	126.63	0.00	0.00	0.00	126.63	0.00	0.00	0.00	0.00	0.00
23170	Warehouse	W	126.65	126.65	0.00	0.00	0.00	11/03/05 9:52 AM	11/08/05 4:30 PM	126.65	0.00	0.00	0.00	126.65	7.27	0.00	0.00	0.00	7.27
23718	Warehouse	W	126.75	126.75	0.00	0.00	0.00	11/03/05 9:46 AM	11/08/05 4:30 PM	126.48	0.00	0.00	0.00	126.48	9.93	0.00	0.00	0.00	9.93
24636	Warehouse	W	158.72	158.72	0.00	0.00	0.00	11/02/05 6:18 PM	11/09/05 9:00 AM	158.72	0.00	0.00	0.00	158.72	51.50	0.00	0.00	0.00	51.50
20935	Warehouse	W	159.22	159.22	0.00	0.00	0.00	11/02/05 5:48 PM	11/09/05 9:00 AM	159.22	0.00	0.00	0.00	159.22	95.88	0.00	0.00	0.00	95.88
22224	Warehouse	W	159.20	159.20	0.00	0.00	0.00	11/02/05 5:49 PM	11/09/05 9:00 AM	159.20	0.00	0.00	0.00	159.20	104.40	0.00	0.00	0.00	104.40
21508	Warehouse	W	158.62	158.62	0.00	0.00	0.00	11/02/05 6:24 PM	11/09/05 9:00 AM	158.62	0.00	0.00	0.00	158.62	29.75	0.00	0.00	0.00	29.75
23557	Warehouse	W	126.70	126.70	0.00	0.00	0.00	11/03/05 9:49 AM	11/08/05 4:30 PM	126.70	0.00	0.00	0.00	126.70	61.53	0.00	0.00	0.00	61.53

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24690	Warehouse	W	850	5.48	0.00	0.00	0.00	5.48	2.07	0.00	0.00	0.00	2.07	62.23%
21805	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	95.66	0.00	0.00	0.00	95.66	43.06%
22992	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	45.44	0.00	0.00	0.00	45.44	72.95%
22378	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	29.67	0.00	0.00	0.00	29.67	82.34%
23394	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	52.56	0.00	0.00	0.00	52.56	68.71%
22988	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	28.04	0.00	0.00	0.00	28.04	83.31%
24700	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	56.14	0.00	0.00	0.00	56.14	66.58%
22825	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	33.25	0.00	0.00	0.00	33.25	80.21%
20974	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	22.93	0.00	0.00	0.00	22.93	86.35%
22506	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	29.10	0.00	0.00	0.00	29.10	82.68%
21174	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	36.11	0.00	0.00	0.00	36.11	78.51%
22279	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	40.81	0.00	0.00	0.00	40.81	75.71%
21996	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	41.43	0.00	0.00	0.00	41.43	75.34%
24042	Warehouse	W	850	167.98	0.00	0.00	0.00	167.98	12.61	0.00	0.00	0.00	12.61	92.49%
20979	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	38.80	0.00	0.00	0.00	38.80	76.90%
23593	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	58.97	0.00	0.00	0.00	58.97	64.90%
20787	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	39.36	0.00	0.00	0.00	39.36	76.57%
21474	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	125.04	0.00	0.00	0.00	125.04	25.57%
23886	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	127.51	0.00	0.00	0.00	127.51	24.10%
23728	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	34.72	0.00	0.00	0.00	34.72	79.33%
23650	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	35.88	0.00	0.00	0.00	35.88	78.64%
23717	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	45.33	0.00	0.00	0.00	45.33	73.02%
21371	Warehouse	W	850	165.75	0.00	0.00	0.00	165.75	42.95	0.00	0.00	0.00	42.95	74.09%
22905	Warehouse	W	850	167.89	0.00	0.00	0.00	167.89	25.28	0.00	0.00	0.00	25.28	84.94%
20943	Warehouse	W	850	167.82	0.00	0.00	0.00	167.82	21.06	0.00	0.00	0.00	21.06	87.45%
21980	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	15.25	0.00	0.00	0.00	15.25	90.92%
21354	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	12.30	0.00	0.00	0.00	12.30	92.68%
21005	Warehouse	W	850	167.96	0.00	0.00	0.00	167.96	17.01	0.00	0.00	0.00	17.01	89.87%
22831	Warehouse	W	850	167.89	0.00	0.00	0.00	167.89	16.45	0.00	0.00	0.00	16.45	90.20%
23561	Warehouse	W	850	167.86	0.00	0.00	0.00	167.86	19.94	0.00	0.00	0.00	19.94	88.12%
23325	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	16.87	0.00	0.00	0.00	16.87	89.96%
21702	Warehouse	W	850	167.91	0.00	0.00	0.00	167.91	17.41	0.00	0.00	0.00	17.41	89.63%
21442	Warehouse	W	850	166.17	0.00	0.00	0.00	166.17	0.00	0.00	0.00	0.00	0.00	00.00%
20683	Warehouse	W	850	167.96	0.00	0.00	0.00	167.96	16.01	0.00	0.00	0.00	16.01	90.47%
21544	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	14.52	0.00	0.00	0.00	14.52	91.36%
21761	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	14.97	0.00	0.00	0.00	14.97	91.09%
22498	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	0.00	0.00	0.00	0.00	0.00	00.00%
23170	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	9.64	0.00	0.00	0.00	9.64	94.26%
23718	Warehouse	W	850	167.65	0.00	0.00	0.00	167.65	13.17	0.00	0.00	0.00	13.17	92.14%
24636	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	54.51	0.00	0.00	0.00	54.51	67.55%
20935	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	101.17	0.00	0.00	0.00	101.17	39.78%
22224	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	110.17	0.00	0.00	0.00	110.17	34.42%
21508	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	31.51	0.00	0.00	0.00	31.51	81.24%
23557	Warehouse	W	850	168.00	0.00	0.00	0.00	168.00	81.59	0.00	0.00	0.00	81.59	51.43%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Warehouse	W	44	37400	6141	0	0	0	6141	1431	0	0	0	1431
Building Totals			37400	6141	0			6141	1431	0			1431